

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
										NA	Air Quality Levels	Site Specific Trigger Levels	
										70			
										Target Air Quality Levels			
										EPA Site Specific Trigger Levels			
ASBESTOS-ST1-1/3/07	030700247-0001	Southwest Area (sidewalk bridge level)	1/3/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/4/07	< 13.00	No	No	
ASBESTOS-ST2-1/3/07	030700247-0002	Southeast Area (sidewalk bridge level)	1/3/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/4/07	< 13.00	No	No	
ASBESTOS-ST4-1/3/07	030700247-0003	Northwest Area (street-level)	1/3/07	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/4/07	< 13.00	No	No	
ASBESTOS-ST5-1/3/07	030700247-0004	Firehouse #10 (roof level)	1/3/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/4/07	< 13.00	No	No	
ASBESTOS-ST10-1/3/07	030700247-0005	North Side Sidewalk Bridge	1/3/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/4/07	< 13.00	No	No	
ASBESTOS-ST11-1/3/07	030700247-0006	90 Trinity Place (roof level)	1/3/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/4/07	< 13.00	No	No	
ASBESTOS-ST12-1/3/07	030700247-0007	110 Greenwich Street (roof level)	1/3/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/4/07	< 13.00	No	No	
ASBESTOS-ST13-1/3/07	030700247-0008	Marriott Hotel, 38th Floor (roof level)	1/3/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/4/07	< 13.00	No	No	
ASBESTOS-ST14-1/3/07	030700247-0009	West Face - South end at corner (scaffolding level)	1/3/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/4/07	< 13.00	No	No	
ASBESTOS-ST15-1/3/07	030700247-0010	South Face - East end at corner (scaffolding level)	1/3/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/4/07	< 13.00	No	No	
ASBESTOS-ST16-1/3/07	030700247-0011	East Face - North end at corner (scaffolding level)	1/3/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/4/07	< 13.00	No	No	
ASBESTOS-ST17-1/3/07	030700247-0012	North Face - West end at corner (scaffolding level)	1/3/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/4/07	< 13.00	No	No	
ASBESTOS-ST1-1/4/07	030700375-0001	Southwest Area (sidewalk bridge level)	1/4/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/5/07	< 13.00	No	No	
ASBESTOS-ST2-1/4/07	030700375-0002	Southeast Area (sidewalk bridge level)	1/4/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/5/07	< 13.00	No	No	
ASBESTOS-ST4-1/4/07	030700375-0003	Northwest Area (street-level)	1/4/07	1	3.410	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/5/07	< 13.00	No	No	Note 1.
ASBESTOS-ST5-1/4/07	030700375-0004	Firehouse #10 (roof level)	1/4/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/5/07	< 13.00	No	No	
ASBESTOS-ST10-1/4/07	030700375-0005	North Side Sidewalk Bridge	1/4/07	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/5/07	< 15.00	No	No	
ASBESTOS-ST11-1/4/07	030700375-0006	90 Trinity Place (roof level)	1/4/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/5/07	< 13.00	No	No	
ASBESTOS-ST12-1/4/07	030700375-0007	110 Greenwich Street (roof level)	1/4/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/5/07	< 13.00	No	No	
ASBESTOS-ST13-1/4/07	030700375-0008	Marriott Hotel, 38th Floor (roof level)	1/4/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/5/07	< 13.00	No	No	
ASBESTOS-ST14-1/4/07	030700375-0009	West Face - South end at corner (scaffolding level)	1/4/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/5/07	< 13.00	No	No	
ASBESTOS-ST15-1/4/07	030700375-0010	South Face - East end at corner (scaffolding level)	1/4/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/5/07	< 13.00	No	No	
ASBESTOS-ST16-1/4/07	030700375-0011	East Face - North end at corner (scaffolding level)	1/4/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/5/07	< 15.00	No	No	
ASBESTOS-ST17-1/4/07	030700375-0012	North Face - West end at corner (scaffolding level)	1/4/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/5/07	< 13.00	No	No	

Note:

1. Due to flow rate RPD exceedance (22.9%) for asbestos at Station 4 (Northwest Area [street-level]) on January 4, 2007, the sample volume and subsequent sample result are estimated.