

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-1/6/09	030900546-0001	Southwest Area (sidewalk bridge level)	1/6/09	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/7/09	< 15.00	No	No	
ASBESTOS-ST2-1/6/09	030900546-0002	Southeast Area (sidewalk bridge level)	1/6/09	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/7/09	< 13.00	No	No	
ASBESTOS-ST4-1/6/09	030900546-0003	Northwest Area (street-level)	1/6/09	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/7/09	< 15.00	No	No	
ASBESTOS-ST5-1/6/09	030900546-0004	Firehouse #10 (roof level)	1/6/09	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/7/09	< 13.00	No	No	
ASBESTOS-ST10-1/6/09	030900546-0005	North Side Sidewalk Bridge	1/6/09	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/7/09	< 15.00	No	No	
ASBESTOS-ST100-1/6/09	030900546-0013	Station 10 Field Duplicate	1/6/09	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/7/09	< 13.00	No	No	
ASBESTOS-ST11-1/6/09	030900546-0006	90 Trinity Place (roof level)	1/6/09	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/7/09	< 13.00	No	No	
ASBESTOS-ST12-1/6/09	030900546-0007	110 Greenwich Street (roof level)	1/6/09	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/7/09	< 13.00	No	No	
ASBESTOS-ST13-1/6/09	030900546-0008	Marriott Hotel, 38th Floor (roof level)	1/6/09	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/7/09	< 13.00	No	No	
ASBESTOS-ST14-1/6/09	030900546-0009	West Face - South end at corner (scaffolding level)	1/6/09	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/7/09	< 15.00	No	No	
ASBESTOS-ST15-1/6/09	030900546-0010	South Face - East end at corner (scaffolding level)	1/6/09	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/7/09	< 13.00	No	No	
ASBESTOS-ST16-1/6/09	030900546-0011	East Face - North end at corner (scaffolding level)	1/6/09	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/7/09	< 13.00	No	No	
ASBESTOS-ST17-1/6/09	030900546-0012	North Face - West end at corner (scaffolding level)	1/6/09	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/7/09	< 13.00	No	No	
ASBESTOS-ST1-1/7/09	030900644-0001	Southwest Area (sidewalk bridge level)	1/7/09	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/8/09	< 13.00	No	No	
ASBESTOS-ST2-1/7/09	030900644-0002	Southeast Area (sidewalk bridge level)	1/7/09	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/8/09	< 13.00	No	No	
ASBESTOS-ST4-1/7/09	030900644-0003	Northwest Area (street-level)	1/7/09	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/8/09	< 13.00	No	No	
ASBESTOS-ST5-1/7/09	030900644-0004	Firehouse #10 (roof level)	1/7/09	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/8/09	< 13.00	No	No	
ASBESTOS-ST10-1/7/09	030900644-0005	North Side Sidewalk Bridge	1/7/09	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/8/09	< 13.00	No	No	
ASBESTOS-ST11-1/7/09	030900644-0006	90 Trinity Place (roof level)	1/7/09	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/8/09	< 13.00	No	No	
ASBESTOS-ST12-1/7/09	030900644-0007	110 Greenwich Street (roof level)	1/7/09	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/8/09	< 13.00	No	No	
ASBESTOS-ST13-1/7/09	030900644-0008	Marriott Hotel, 38th Floor (roof level)	1/7/09	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/8/09	< 13.00	No	No	
ASBESTOS-ST14-1/7/09	030900644-0009	West Face - South end at corner (scaffolding level)	1/7/09	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/8/09	< 13.00	No	No	
ASBESTOS-ST15-1/7/09	030900644-0010	South Face - East end at corner (scaffolding level)	1/7/09	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/8/09	< 13.00	No	No	
ASBESTOS-ST16-1/7/09	030900644-0011	East Face - North end at corner (scaffolding level)	1/7/09	1	2.930	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/8/09	< 13.00	No	No	
ASBESTOS-ST17-1/7/09	030900644-0012	North Face - West end at corner (scaffolding level)	1/7/09	1	2.910	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/8/09	< 13.00	No	No	
ASBESTOS-ST1-1/8/09	030900780-0001	Southwest Area (sidewalk bridge level)	1/8/09	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/9/09	< 15.00	No	No	
ASBESTOS-ST2-1/8/09	030900780-0002	Southeast Area (sidewalk bridge level)	1/8/09	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/9/09	< 15.00	No	No	
ASBESTOS-ST4-1/8/09	030900780-0003	Northwest Area (street-level)	1/8/09	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/9/09	< 13.00	No	No	
ASBESTOS-ST5-1/8/09	030900780-0004	Firehouse #10 (roof level)	1/8/09	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/9/09	< 13.00	No	No	
ASBESTOS-ST10-1/8/09	030900780-0005	North Side Sidewalk Bridge	1/8/09	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/9/09	< 13.00	No	No	
ASBESTOS-ST11-1/8/09	030900780-0006	90 Trinity Place (roof level)	1/8/09	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/9/09	< 13.00	No	No	
ASBESTOS-ST12-1/8/09	030900780-0007	110 Greenwich Street (roof level)	1/8/09	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/9/09	< 13.00	No	No	
ASBESTOS-ST13-1/8/09	030900780-0008	Marriott Hotel, 38th Floor (roof level)	1/8/09	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/9/09	< 13.00	No	No	
ASBESTOS-ST14-1/8/09	030900780-0009	West Face - South end at corner (scaffolding level)	1/8/09	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/9/09	< 13.00	No	No	
ASBESTOS-ST15-1/8/09	030900780-0010	South Face - East end at corner (scaffolding level)	1/8/09	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/9/09	< 13.00	No	No	
ASBESTOS-ST16-1/8/09	030900780-0011	East Face - North end at corner (scaffolding level)	1/8/09	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/9/09	< 13.00	No	No	
ASBESTOS-ST17-1/8/09	030900780-0012	North Face - West end at corner (scaffolding level)	1/8/09	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/9/09	< 13.00	No	No	