

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-1/17/06	030601653-0001	Southwest Area (sidewalk bridge level)	1/17/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/18/06	< 13.00	No	No	
ASBESTOS-ST2-1/17/06	030601653-0002	Southeast Area (sidewalk bridge level)	1/17/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/18/06	< 13.00	No	No	
ASBESTOS-ST4-1/17/06	030601653-0003	Northwest Area (street-level)	1/17/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/18/06	< 13.00	No	No	
ASBESTOS-ST5-1/17/06	030601653-0004	Firehouse #10 (roof level)	1/17/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/18/06	< 13.00	No	No	
ASBESTOS-ST10-1/17/06	030601653-0005	North Side Sidewalk Bridge	1/17/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/18/06	< 13.00	No	No	
ASBESTOS-ST11-1/17/06	030601653-0006	90 Trinity Place (roof level)	1/17/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/18/06	< 13.00	No	No	
ASBESTOS-ST12-1/17/06	030601653-0007	110 Greenwich Street (roof level)	1/17/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/18/06	< 13.00	No	No	
ASBESTOS-ST13-1/17/06	030601653-0008	Marriott Hotel, 38th Floor (roof level)	1/17/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/18/06	< 13.00	No	No	
ASBESTOS-ST14-1/17/06	030601785-0013	West Face - South end at corner (scaffolding level)	1/17/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/19/06	< 13.00	No	No	
ASBESTOS-ST15-1/17/06	030601785-0014	South Face - East end at corner (scaffolding level)	1/17/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/19/06	< 13.00	No	No	
ASBESTOS-ST16-1/17/06	030601785-0015	East Face - North end at corner (scaffolding level)	1/17/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/19/06	< 13.00	No	No	
ASBESTOS-ST17-1/17/06	030601785-0016	North Face - West end at corner (scaffolding level)	1/17/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/19/06	< 13.00	No	No	
ASBESTOS-ST1-1/18/06	030601785-0001	Southwest Area (sidewalk bridge level)	1/18/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/19/06	< 13.00	No	No	
ASBESTOS-ST2-1/18/06	030601785-0002	Southeast Area (sidewalk bridge level)	1/18/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/19/06	< 13.00	No	No	
ASBESTOS-ST4-1/18/06	030601785-0003	Northwest Area (street-level)	1/18/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/19/06	< 13.00	No	No	
ASBESTOS-ST5-1/18/06	030601785-0004	Firehouse #10 (roof level)	1/18/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/19/06	< 13.00	No	No	
ASBESTOS-ST10-1/18/06	030601785-0005	North Side Sidewalk Bridge	1/18/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/19/06	< 13.00	No	No	
ASBESTOS-ST11-1/18/06	030601785-0006	90 Trinity Place (roof level)	1/18/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/19/06	< 13.00	No	No	
ASBESTOS-ST12-1/18/06	030601785-0007	110 Greenwich Street (roof level)	1/18/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/19/06	< 13.00	No	No	
ASBESTOS-ST13-1/18/06	030601785-0008	Marriott Hotel, 38th Floor (roof level)	1/18/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/19/06	< 13.00	No	No	
ASBESTOS-ST14-1/18/06	030601785-0009	West Face - South end at corner (scaffolding level)	1/18/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/19/06	< 13.00	No	No	
ASBESTOS-ST15-1/18/06	030601785-0010	South Face - East end at corner (scaffolding level)	1/18/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/19/06	< 13.00	No	No	
ASBESTOS-ST16-1/18/06	030601785-0011	East Face - North end at corner (scaffolding level)	1/18/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/19/06	< 13.00	No	No	
ASBESTOS-ST17-1/18/06	030601785-0012	North Face - West end at corner (scaffolding level)	1/18/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/19/06	< 13.00	No	No	