

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-1/19/07	030702107-0001	Southwest Area (sidewalk bridge level)	1/19/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 15.00	No	No	
ASBESTOS-ST2-1/19/07	030702107-0002	Southeast Area (sidewalk bridge level)	1/19/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 13.00	No	No	
ASBESTOS-ST4-1/19/07	030702107-0003	Northwest Area (street-level)	1/19/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 15.00	No	No	
ASBESTOS-ST5-1/19/07	030702107-0004	Firehouse #10 (roof level)	1/19/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 15.00	No	No	
ASBESTOS-ST10-1/19/07	030702107-0005	North Side Sidewalk Bridge	1/19/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 15.00	No	No	
ASBESTOS-ST11-1/19/07	030702107-0006	90 Trinity Place (roof level)	1/19/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 13.00	No	No	
ASBESTOS-ST12-1/19/07	030702107-0007	110 Greenwich Street (roof level)	1/19/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 13.00	No	No	
ASBESTOS-ST13-1/19/07	030702107-0008	Marriott Hotel, 38th Floor (roof level)	1/19/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 13.00	No	No	
ASBESTOS-ST14-1/19/07	030702107-0009	West Face - South end at corner (scaffolding level)	1/19/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 13.00	No	No	
ASBESTOS-ST15-1/19/07	030702107-0010	South Face - East end at corner (scaffolding level)	1/19/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 13.00	No	No	
ASBESTOS-ST16-1/19/07	030702107-0011	East Face - North end at corner (scaffolding level)	1/19/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 13.00	No	No	
ASBESTOS-ST17-1/19/07	030702107-0012	North Face - West end at corner (scaffolding level)	1/19/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 13.00	No	No	
ASBESTOS-ST1-1/20/07	030702109-0001	Southwest Area (sidewalk bridge level)	1/20/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 15.00	No	No	
ASBESTOS-ST2-1/20/07	030702109-0002	Southeast Area (sidewalk bridge level)	1/20/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 13.00	No	No	
ASBESTOS-ST4-1/20/07	030702109-0003	Northwest Area (street-level)	1/20/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 15.00	No	No	
ASBESTOS-ST5-1/20/07	030702109-0004	Firehouse #10 (roof level)	1/20/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 13.00	No	No	
ASBESTOS-ST10-1/20/07	030702109-0005	North Side Sidewalk Bridge	1/20/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 13.00	No	No	
ASBESTOS-ST11-1/20/07	030702109-0006	90 Trinity Place (roof level)	1/20/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 13.00	No	No	
ASBESTOS-ST12-1/20/07	030702109-0007	110 Greenwich Street (roof level)	1/20/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 13.00	No	No	
ASBESTOS-ST13-1/20/07	030702109-0008	Marriott Hotel, 38th Floor (roof level)	1/20/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 13.00	No	No	
ASBESTOS-ST14-1/20/07	030702109-0009	West Face - South end at corner (scaffolding level)	1/20/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 15.00	No	No	
ASBESTOS-ST15-1/20/07	030702109-0010	South Face - East end at corner (scaffolding level)	1/20/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 13.00	No	No	
ASBESTOS-ST16-1/20/07	030702109-0011	East Face - North end at corner (scaffolding level)	1/20/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 13.00	No	No	
ASBESTOS-ST17-1/20/07	030702109-0012	North Face - West end at corner (scaffolding level)	1/20/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 13.00	No	No	
ASBESTOS-ST1-1/21/07	030702106-0001	Southwest Area (sidewalk bridge level)	1/21/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 13.00	No	No	
ASBESTOS-ST2-1/21/07	030702106-0002	Southeast Area (sidewalk bridge level)	1/21/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 13.00	No	No	
ASBESTOS-ST4-1/21/07	030702106-0003	Northwest Area (street-level)	1/21/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 13.00	No	No	
ASBESTOS-ST5-1/21/07	030702106-0004	Firehouse #10 (roof level)	1/21/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 13.00	No	No	
ASBESTOS-ST10-1/21/07	030702106-0005	North Side Sidewalk Bridge	1/21/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 13.00	No	No	
ASBESTOS-ST11-1/21/07	030702106-0006	90 Trinity Place (roof level)	1/21/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 13.00	No	No	
ASBESTOS-ST12-1/21/07	030702106-0007	110 Greenwich Street (roof level)	1/21/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 13.00	No	No	
ASBESTOS-ST13-1/21/07	030702106-0008	Marriott Hotel, 38th Floor (roof level)	1/21/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 13.00	No	No	
ASBESTOS-ST14-1/21/07	030702106-0009	West Face - South end at corner (scaffolding level)	1/21/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 13.00	No	No	
ASBESTOS-ST15-1/21/07	030702106-0010	South Face - East end at corner (scaffolding level)	1/21/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 13.00	No	No	
ASBESTOS-ST16-1/21/07	030702106-0011	East Face - North end at corner (scaffolding level)	1/21/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 13.00	No	No	
ASBESTOS-ST17-1/21/07	030702106-0012	North Face - West end at corner (scaffolding level)	1/21/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/07	< 13.00	No	No	