

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
										NA			
										70			
Target Air Quality Levels													
EPA Site Specific Trigger Levels													
ASBESTOS-ST1-1/24/06	030602413-0001	Southwest Area (sidewalk bridge level)	1/24/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/25/06	< 13.00	No	No	
ASBESTOS-ST2-1/24/06	030602413-0002	Southeast Area (sidewalk bridge level)	1/24/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/25/06	< 13.00	No	No	
ASBESTOS-ST4-1/24/06	030602413-0003	Northwest Area (street-level)	1/24/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/25/06	< 13.00	No	No	
ASBESTOS-ST5-1/24/06	030602413-0004	Firehouse #10 (roof level)	1/24/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/25/06	< 13.00	No	No	
ASBESTOS-ST10-1/24/06	030602413-0005	North Side Sidewalk Bridge	1/24/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/25/06	< 13.00	No	No	
ASBESTOS-ST100-1/24/06	030602413-0013	Station 10 Field Duplicate	1/24/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/25/06	< 13.00	No	No	
ASBESTOS-ST11-1/24/06	030602413-0006	90 Trinity Place (roof level)	1/24/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/25/06	< 13.00	No	No	
ASBESTOS-ST12-1/24/06	030602413-0007	110 Greenwich Street (roof level)	1/24/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/25/06	< 13.00	No	No	
ASBESTOS-ST13-1/24/06	030602413-0008	Marriott Hotel, 38th Floor (roof level)	1/24/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/25/06	< 13.00	No	No	
ASBESTOS-ST14-1/24/06	030602413-0009	West Face - South end at corner (scaffolding level)	1/24/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/25/06	< 13.00	No	No	
ASBESTOS-ST15-1/24/06	030602413-0010	South Face - East end at corner (scaffolding level)	1/24/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/25/06	< 13.00	No	No	
ASBESTOS-ST16-1/24/06	030602413-0011	East Face - North end at corner (scaffolding level)	1/24/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/25/06	< 13.00	No	No	
ASBESTOS-ST17-1/24/06	030602413-0012	North Face - West end at corner (scaffolding level)	1/24/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/25/06	< 13.00	No	No	
ASBESTOS-ST1-1/25/06	030602557-0001	Southwest Area (sidewalk bridge level)	1/25/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/26/06	< 13.00	No	No	
ASBESTOS-ST2-1/25/06	030602557-0002	Southeast Area (sidewalk bridge level)	1/25/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/26/06	< 13.00	No	No	
ASBESTOS-ST4-1/25/06	030602557-0003	Northwest Area (street-level)	1/25/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/26/06	< 13.00	No	No	
ASBESTOS-ST5-1/25/06	030602557-0004	Firehouse #10 (roof level)	1/25/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/26/06	< 13.00	No	No	
ASBESTOS-ST10-1/25/06	030602557-0005	North Side Sidewalk Bridge	1/25/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/26/06	< 13.00	No	No	
ASBESTOS-ST11-1/25/06	030602557-0006	90 Trinity Place (roof level)	1/25/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/26/06	< 13.00	No	No	
ASBESTOS-ST12-1/25/06	030602557-0007	110 Greenwich Street (roof level)	1/25/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/26/06	< 13.00	No	No	
ASBESTOS-ST13-1/25/06	030602557-0008	Marriott Hotel, 38th Floor (roof level)	1/25/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/26/06	< 13.00	No	No	
ASBESTOS-ST14-1/25/06	030602557-0009	West Face - South end at corner (scaffolding level)	1/25/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/26/06	< 13.00	No	No	
ASBESTOS-ST15-1/25/06	030602557-0010	South Face - East end at corner (scaffolding level)	1/25/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/26/06	< 13.00	No	No	
ASBESTOS-ST16-1/25/06	030602557-0011	East Face - North end at corner (scaffolding level)	1/25/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/26/06	< 13.00	No	No	
ASBESTOS-ST17-1/25/06	030602557-0012	North Face - West end at corner (scaffolding level)	1/25/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/26/06	< 13.00	No	No	