

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
										NA	Air Quality Levels	Site Specific Trigger Levels	
										70			
										EPA Site Specific Trigger Levels			
ASBESTOS-ST1-1/24/07	030702486-0001	Southwest Area (sidewalk bridge level)	1/24/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/25/07	< 13.00	No	No	
ASBESTOS-ST2-1/24/07	030702486-0002	Southeast Area (sidewalk bridge level)	1/24/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/25/07	< 15.00	No	No	
ASBESTOS-ST4-1/24/07	030702486-0003	Northwest Area (street-level)	1/24/07	1	3.210	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/25/07	< 15.00	No	No	
ASBESTOS-ST5-1/24/07	030702486-0004	Firehouse #10 (roof level)	1/24/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/25/07	< 15.00	No	No	
ASBESTOS-ST10-1/24/07	030702486-0005	North Side Sidewalk Bridge	1/24/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/25/07	< 15.00	No	No	
ASBESTOS-ST11-1/24/07	030702486-0006	90 Trinity Place (roof level)	1/24/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/25/07	< 13.00	No	No	
ASBESTOS-ST12-1/24/07	030702486-0007	110 Greenwich Street (roof level)	1/24/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/25/07	< 15.00	No	No	
ASBESTOS-ST13-1/24/07	030702486-0008	Marriott Hotel, 38th Floor (roof level)	1/24/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/25/07	< 13.00	No	No	
ASBESTOS-ST14-1/24/07	030702486-0009	West Face - South end at corner (scaffolding level)	1/24/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/25/07	< 15.00	No	No	
ASBESTOS-ST15-1/24/07	030702486-0010	South Face - East end at corner (scaffolding level)	1/24/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/25/07	< 15.00	No	No	
ASBESTOS-ST16-1/24/07	030702486-0011	East Face - North end at corner (scaffolding level)	1/24/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/25/07	< 13.00	No	No	
ASBESTOS-ST17-1/24/07	030702486-0012	North Face - West end at corner (scaffolding level)	1/24/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/25/07	< 13.00	No	No	
ASBESTOS-ST1-1/25/07	030702646-0001	Southwest Area (sidewalk bridge level)	1/25/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/26/07	< 13.00	No	No	
ASBESTOS-ST2-1/25/07	030702646-0002	Southeast Area (sidewalk bridge level)	1/25/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/26/07	< 13.00	No	No	
ASBESTOS-ST5-1/25/07	030702646-0003	Firehouse #10 (roof level)	1/25/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/26/07	< 13.00	No	No	
ASBESTOS-ST10-1/25/07	030702646-0004	North Side Sidewalk Bridge	1/25/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/26/07	< 13.00	No	No	
ASBESTOS-ST11-1/25/07	030702646-0005	90 Trinity Place (roof level)	1/25/07	1	2.880	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/26/07	< 13.00	No	No	
ASBESTOS-ST12-1/25/07	030702646-0006	110 Greenwich Street (roof level)	1/25/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/26/07	< 13.00	No	No	
ASBESTOS-ST13-1/25/07	030702646-0007	Marriott Hotel, 38th Floor (roof level)	1/25/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/26/07	< 13.00	No	No	
ASBESTOS-ST14-1/25/07	030702646-0008	West Face - South end at corner (scaffolding level)	1/25/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/26/07	< 13.00	No	No	
ASBESTOS-ST15-1/25/07	030702646-0009	South Face - East end at corner (scaffolding level)	1/25/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/26/07	< 13.00	No	No	
ASBESTOS-ST16-1/25/07	030702646-0010	East Face - North end at corner (scaffolding level)	1/25/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/26/07	< 13.00	No	No	
ASBESTOS-ST17-1/25/07	030702646-0011	North Face - West end at corner (scaffolding level)	1/25/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/26/07	< 13.00	No	No	

Note:

- Asbestos sample at Station 4 (Northwest Area [street-level]) on January 25, 2007 was not available for analysis on account of pump failure.