

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality	Site Specific	Comments
EPA Site Specific Trigger Levels										70	Levels	Trigger Levels	
ASBESTOS-ST1-2/4/08	030803078-0001	Southwest Area (sidewalk bridge level)	2/4/08	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/5/08	< 13.00	No	No	
ASBESTOS-ST2-2/4/08	030803078-0002	Southeast Area (sidewalk bridge level)	2/4/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/5/08	13.00	No	No	
ASBESTOS-ST4-2/4/08	030803078-0003	Northwest Area (street-level)	2/4/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/5/08	< 13.00	No	No	
ASBESTOS-ST5-2/4/08	030803078-0004	Firehouse #10 (roof level)	2/4/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/5/08	< 13.00	No	No	
ASBESTOS-ST10-2/4/08	030803078-0005	North Side Sidewalk Bridge	2/4/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/5/08	< 13.00	No	No	
ASBESTOS-ST11-2/4/08	030803078-0006	90 Trinity Place (roof level)	2/4/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/5/08	< 13.00	No	No	
ASBESTOS-ST12-2/4/08	030803078-0007	110 Greenwich Street (roof level)	2/4/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/5/08	< 13.00	No	No	
ASBESTOS-ST13-2/4/08	030803078-0008	Marriott Hotel, 38th Floor (roof level)	2/4/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/5/08	< 13.00	No	No	
ASBESTOS-ST14-2/4/08	030803078-0009	West Face - South end at corner (scaffolding level)	2/4/08	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/5/08	< 13.00	No	No	
ASBESTOS-ST15-2/4/08	030803078-0010	South Face - East end at corner (scaffolding level)	2/4/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/5/08	< 13.00	No	No	
ASBESTOS-ST16-2/4/08	030803078-0011	East Face - North end at corner (scaffolding level)	2/4/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/5/08	< 13.00	No	No	
ASBESTOS-ST17-2/4/08	030803078-0012	North Face - West end at corner (scaffolding level)	2/4/08	1	2.850	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/5/08	< 13.00	No	No	