

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)		Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
										NA				
										70				
<b>Target Air Quality Levels</b>														
<b>EPA Site Specific Trigger Levels</b>														
ASBESTOS-ST1-2/5/08	030803276-0001	Southwest Area (sidewalk bridge level)	2/5/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/7/08	< 13.00	No	No		
ASBESTOS-ST2-2/5/08	030803276-0002	Southeast Area (sidewalk bridge level)	2/5/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/7/08	< 13.00	No	No		
ASBESTOS-ST4-2/5/08	030803276-0003	Northwest Area (street-level)	2/5/08	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/7/08	< 13.00	No	No		
ASBESTOS-ST5-2/5/08	030803276-0004	Firehouse #10 (roof level)	2/5/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/7/08	< 13.00	No	No		
ASBESTOS-ST10-2/5/08	030803276-0005	North Side Sidewalk Bridge	2/5/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/7/08	< 13.00	No	No		
ASBESTOS-ST11-2/5/08	030803276-0006	90 Trinity Place (roof level)	2/5/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/7/08	< 13.00	No	No		
ASBESTOS-ST12-2/5/08	030803276-0007	110 Greenwich Street (roof level)	2/5/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/7/08	< 13.00	No	No		
ASBESTOS-ST13-2/5/08	030803276-0008	Marriott Hotel, 38th Floor (roof level)	2/5/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/7/08	< 13.00	No	No		
ASBESTOS-ST14-2/5/08	030803276-0009	West Face - South end at corner (scaffolding level)	2/5/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/7/08	< 13.00	No	No		
ASBESTOS-ST15-2/5/08	030803276-0010	South Face - East end at corner (scaffolding level)	2/5/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/7/08	< 13.00	No	No		
ASBESTOS-ST16-2/5/08	030803276-0011	East Face - North end at corner (scaffolding level)	2/5/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/7/08	< 13.00	No	No		
ASBESTOS-ST17-2/5/08	030803276-0012	North Face - West end at corner (scaffolding level)	2/5/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/7/08	< 13.00	No	No		
ASBESTOS-ST1-2/6/08	030803281-0001	Southwest Area (sidewalk bridge level)	2/6/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/7/08	< 13.00	No	No		
ASBESTOS-ST2-2/6/08	030803281-0002	Southeast Area (sidewalk bridge level)	2/6/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/7/08	< 15.00	No	No		
ASBESTOS-ST4-2/6/08	030803281-0003	Northwest Area (street-level)	2/6/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/7/08	< 13.00	No	No		
ASBESTOS-ST5-2/6/08	030803281-0004	Firehouse #10 (roof level)	2/6/08	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/7/08	< 13.00	No	No		
ASBESTOS-ST10-2/6/08	030803281-0005	North Side Sidewalk Bridge	2/6/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/7/08	< 13.00	No	No		
ASBESTOS-ST11-2/6/08	030803281-0006	90 Trinity Place (roof level)	2/6/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/7/08	< 13.00	No	No		
ASBESTOS-ST12-2/6/08	030803281-0007	110 Greenwich Street (roof level)	2/6/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/7/08	< 13.00	No	No		
ASBESTOS-ST13-2/6/08	030803281-0008	Marriott Hotel, 38th Floor (roof level)	2/6/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/7/08	< 13.00	No	No		
ASBESTOS-ST14-2/6/08	030803281-0009	West Face - South end at corner (scaffolding level)	2/6/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/7/08	< 13.00	No	No		
ASBESTOS-ST15-2/6/08	030803281-0010	South Face - East end at corner (scaffolding level)	2/6/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/7/08	< 15.00	No	No		
ASBESTOS-ST16-2/6/08	030803281-0011	East Face - North end at corner (scaffolding level)	2/6/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/7/08	< 13.00	No	No		
ASBESTOS-ST17-2/6/08	030803281-0012	North Face - West end at corner (scaffolding level)	2/6/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/7/08	< 15.00	No	No		
ASBESTOS-ST1-2/7/08	030803385-0001	Southwest Area (sidewalk bridge level)	2/7/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/8/08	< 13.00	No	No		
ASBESTOS-ST2-2/7/08	030803385-0002	Southeast Area (sidewalk bridge level)	2/7/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/8/08	< 13.00	No	No		
ASBESTOS-ST4-2/7/08	030803385-0003	Northwest Area (street-level)	2/7/08	1	3.200	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/8/08	< 13.00	No	No		
ASBESTOS-ST5-2/7/08	030803385-0004	Firehouse #10 (roof level)	2/7/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/8/08	< 13.00	No	No		
ASBESTOS-ST10-2/7/08	030803385-0005	North Side Sidewalk Bridge	2/7/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/8/08	< 13.00	No	No		
ASBESTOS-ST100-2/7/08	030803385-0013	Station 10 Field Duplicate	2/7/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/8/08	< 13.00	No	No		
ASBESTOS-ST11-2/7/08	030803385-0006	90 Trinity Place (roof level)	2/7/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/8/08	< 13.00	No	No		
ASBESTOS-ST12-2/7/08	030803385-0007	110 Greenwich Street (roof level)	2/7/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/8/08	< 13.00	No	No		
ASBESTOS-ST13-2/7/08	030803385-0008	Marriott Hotel, 38th Floor (roof level)	2/7/08	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/8/08	< 13.00	No	No		
ASBESTOS-ST14-2/7/08	030803385-0009	West Face - South end at corner (scaffolding level)	2/7/08	1	2.790	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/8/08	< 13.00	No	No		
ASBESTOS-ST15-2/7/08	030803385-0010	South Face - East end at corner (scaffolding level)	2/7/08	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/8/08	< 13.00	No	No		
ASBESTOS-ST16-2/7/08	030803385-0011	East Face - North end at corner (scaffolding level)	2/7/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/8/08	< 13.00	No	No		
ASBESTOS-ST17-2/7/08	030803385-0012	North Face - West end at corner (scaffolding level)	2/7/08	1	2.770	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/8/08	< 13.00	No	No		
ASBESTOS-ST1-2/8/08	030803441-0001	Southwest Area (sidewalk bridge level)	2/8/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/9/08	< 13.00	No	No		
ASBESTOS-ST2-2/8/08	030803441-0002	Southeast Area (sidewalk bridge level)	2/8/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/9/08	< 13.00	No	No		
ASBESTOS-ST4-2/8/08	030803441-0003	Northwest Area (street-level)	2/8/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/9/08	< 13.00	No	No		
ASBESTOS-ST5-2/8/08	030803441-0004	Firehouse #10 (roof level)	2/8/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/9/08	< 13.00	No	No		
ASBESTOS-ST10-2/8/08	030803441-0005	North Side Sidewalk Bridge	2/8/08	1	2.810	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/9/08	< 13.00	No	No		
ASBESTOS-ST11-2/8/08	030803441-0006	90 Trinity Place (roof level)	2/8/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/9/08	< 13.00	No	No		
ASBESTOS-ST12-2/8/08	030803441-0007	110 Greenwich Street (roof level)	2/8/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/9/08	< 13.00	No	No		
ASBESTOS-ST13-2/8/08	030803441-0008	Marriott Hotel, 38th Floor (roof level)	2/8/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/9/08	< 13.00	No	No		
ASBESTOS-ST14-2/8/08	030803441-0009	West Face - South end at corner (scaffolding level)	2/8/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/9/08	< 13.00	No	No		
ASBESTOS-ST15-2/8/08	030803441-0010	South Face - East end at corner (scaffolding level)	2/8/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/9/08	< 13.00	No	No		
ASBESTOS-ST16-2/8/08	030803441-0011	East Face - North end at corner (scaffolding level)	2/8/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/9/08	< 13.00	No	No		
ASBESTOS-ST17-2/8/08	030803441-0012	North Face - West end at corner (scaffolding level)	2/8/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/9/08	< 13.00	No	No		