

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
										NA	Air Quality Levels	Site Specific Trigger Levels	
										70			
										Target Air Quality Levels			
										EPA Site Specific Trigger Levels			
ASBESTOS-ST1-2/7/07	030704012-0001	Southwest Area (sidewalk bridge level)	2/7/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/8/07	< 13.00	No	No	
ASBESTOS-ST2-2/7/07	030704012-0002	Southeast Area (sidewalk bridge level)	2/7/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/8/07	< 13.00	No	No	
ASBESTOS-ST4-2/7/07	030704012-0003	Northwest Area (street-level)	2/7/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/8/07	< 15.00	No	No	
ASBESTOS-ST5-2/7/07	030704012-0004	Firehouse #10 (roof level)	2/7/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/8/07	< 15.00	No	No	
ASBESTOS-ST10-2/7/07	030704012-0005	North Side Sidewalk Bridge	2/7/07	1	2.900	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/8/07	< 13.00	No	No	
ASBESTOS-ST11-2/7/07	030704012-0006	90 Trinity Place (roof level)	2/7/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/8/07	< 15.00	No	No	
ASBESTOS-ST12-2/7/07	030704012-0007	110 Greenwich Street (roof level)	2/7/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/8/07	< 13.00	No	No	
ASBESTOS-ST13-2/7/07	030704012-0008	Marriott Hotel, 38th Floor (roof level)	2/7/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/8/07	< 13.00	No	No	
ASBESTOS-ST14-2/7/07	030704012-0009	West Face - South end at corner (scaffolding level)	2/7/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/8/07	< 13.00	No	No	
ASBESTOS-ST15-2/7/07	030704012-0010	South Face - East end at corner (scaffolding level)	2/7/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/8/07	< 13.00	No	No	
ASBESTOS-ST16-2/7/07	030704012-0011	East Face - North end at corner (scaffolding level)	2/7/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/8/07	< 13.00	No	No	
ASBESTOS-ST17-2/7/07	030704012-0012	North Face - West end at corner (scaffolding level)	2/7/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/8/07	< 13.00	No	No	
ASBESTOS-ST1-2/8/07	030704118-0001	Southwest Area (sidewalk bridge level)	2/8/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/9/07	< 13.00	No	No	
ASBESTOS-ST2-2/8/07	030704118-0002	Southeast Area (sidewalk bridge level)	2/8/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/9/07	< 13.00	No	No	
ASBESTOS-ST4-2/8/07	030704118-0003	Northwest Area (street-level)	2/8/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/9/07	< 13.00	No	No	
ASBESTOS-ST5-2/8/07	030704118-0004	Firehouse #10 (roof level)	2/8/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/9/07	< 13.00	No	No	
ASBESTOS-ST10-2/8/07	030704118-0005	North Side Sidewalk Bridge	2/8/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/9/07	< 13.00	No	No	
ASBESTOS-ST100-2/8/07	030704118-0013	Station 10 Field Duplicate	2/8/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/9/07	< 13.00	No	No	
ASBESTOS-ST11-2/8/07	030704118-0006	90 Trinity Place (roof level)	2/8/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/9/07	< 13.00	No	No	
ASBESTOS-ST12-2/8/07	030704118-0007	110 Greenwich Street (roof level)	2/8/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/9/07	< 13.00	No	No	
ASBESTOS-ST13-2/8/07	030704118-0008	Marriott Hotel, 38th Floor (roof level)	2/8/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/9/07	< 13.00	No	No	
ASBESTOS-ST14-2/8/07	030704118-0009	West Face - South end at corner (scaffolding level)	2/8/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/9/07	< 13.00	No	No	
ASBESTOS-ST15-2/8/07	030704118-0010	South Face - East end at corner (scaffolding level)	2/8/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/9/07	< 13.00	No	No	
ASBESTOS-ST16-2/8/07	030704118-0011	East Face - North end at corner (scaffolding level)	2/8/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/9/07	< 13.00	No	No	
ASBESTOS-ST17-2/8/07	030704118-0012	North Face - West end at corner (scaffolding level)	2/8/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/9/07	< 13.00	No	No	