

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
										NA	Air Quality Levels	Site Specific Trigger Levels	
										70			
Target Air Quality Levels													
EPA Site Specific Trigger Levels													
ASBESTOS-ST1-2/12/08	030803802-0001	Southwest Area (sidewalk bridge level)	2/12/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/13/08	< 13.00	No	No	
ASBESTOS-ST2-2/12/08	030803802-0002	Southeast Area (sidewalk bridge level)	2/12/08	1	3.180	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/13/08	< 13.00	No	No	
ASBESTOS-ST4-2/12/08	030803802-0003	Northwest Area (street-level)	2/12/08	1	3.230	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/13/08	< 13.00	No	No	
ASBESTOS-ST5-2/12/08	030803802-0004	Firehouse #10 (roof level)	2/12/08	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/13/08	< 13.00	No	No	
ASBESTOS-ST10-2/12/08	030803802-0005	North Side Sidewalk Bridge	2/12/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/13/08	< 13.00	No	No	
ASBESTOS-ST11-2/12/08	030803802-0006	90 Trinity Place (roof level)	2/12/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/13/08	< 13.00	No	No	
ASBESTOS-ST12-2/12/08	030803802-0007	110 Greenwich Street (roof level)	2/12/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/13/08	< 13.00	No	No	
ASBESTOS-ST13-2/12/08	030803802-0008	Marriott Hotel, 38th Floor (roof level)	2/12/08	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/13/08	< 13.00	No	No	
ASBESTOS-ST14-2/12/08	030803802-0009	West Face - South end at corner (scaffolding level)	2/12/08	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/13/08	< 13.00	No	No	
ASBESTOS-ST15-2/12/08	030803802-0010	South Face - East end at corner (scaffolding level)	2/12/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/13/08	< 13.00	No	No	
ASBESTOS-ST16-2/12/08	030803802-0011	East Face - North end at corner (scaffolding level)	2/12/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/13/08	< 13.00	No	No	
ASBESTOS-ST17-2/12/08	030803802-0012	North Face - West end at corner (scaffolding level)	2/12/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/13/08	< 13.00	No	No	