

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
										NA	Air Quality Levels	Site Specific Trigger Levels	
										70			
ASBESTOS-ST1-3/1/06	030606510-0001	Southwest Area (sidewalk bridge level)	3/1/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/2/06	< 13.00	No	No	
ASBESTOS-ST2-3/1/06	030606510-0002	Southeast Area (sidewalk bridge level)	3/1/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/2/06	< 13.00	No	No	
ASBESTOS-ST4-3/1/06	030606510-0003	Northwest Area (street-level)	3/1/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/2/06	< 13.00	No	No	
ASBESTOS-ST5-3/1/06	030606510-0004	Firehouse #10 (roof level)	3/1/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/2/06	< 13.00	No	No	
ASBESTOS-ST10-3/1/06	030606510-0005	North Side Sidewalk Bridge	3/1/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/2/06	< 13.00	No	No	
ASBESTOS-ST11-3/1/06	030606510-0006	90 Trinity Place (roof level)	3/1/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/2/06	< 13.00	No	No	
ASBESTOS-ST12-3/1/06	030606510-0007	110 Greenwich Street (roof level)	3/1/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/2/06	< 13.00	No	No	
ASBESTOS-ST13-3/1/06	030606510-0008	Marriott Hotel, 38th Floor (roof level)	3/1/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/2/06	< 13.00	No	No	
ASBESTOS-ST14-3/1/06	030606510-0009	West Face - South end at corner (scaffolding level)	3/1/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/2/06	< 13.00	No	No	
ASBESTOS-ST15-3/1/06	030606510-0010	South Face - East end at corner (scaffolding level)	3/1/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/2/06	< 13.00	No	No	
ASBESTOS-ST16-3/1/06	030606510-0011	East Face - North end at corner (scaffolding level)	3/1/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/2/06	< 13.00	No	No	
ASBESTOS-ST17-3/1/06	030606510-0012	North Face - West end at corner (scaffolding level)	3/1/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/2/06	< 13.00	No	No	
ASBESTOS-ST1-3/2/06	030606628-0001	Southwest Area (sidewalk bridge level)	3/2/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/3/06	< 13.00	No	No	
ASBESTOS-ST2-3/2/06	030606628-0002	Southeast Area (sidewalk bridge level)	3/2/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/3/06	< 13.00	No	No	
ASBESTOS-ST4-3/2/06	030606628-0003	Northwest Area (street-level)	3/2/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/3/06	< 13.00	No	No	
ASBESTOS-ST5-3/2/06	030606628-0004	Firehouse #10 (roof level)	3/2/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/3/06	< 13.00	No	No	
ASBESTOS-ST10-3/2/06	030606628-0005	North Side Sidewalk Bridge	3/2/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/3/06	< 13.00	No	No	
ASBESTOS-ST11-3/2/06	030606628-0006	90 Trinity Place (roof level)	3/2/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/3/06	< 13.00	No	No	
ASBESTOS-ST12-3/2/06	030606628-0007	110 Greenwich Street (roof level)	3/2/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/3/06	< 13.00	No	No	
ASBESTOS-ST13-3/2/06	030606628-0008	Marriott Hotel, 38th Floor (roof level)	3/2/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/3/06	< 13.00	No	No	
ASBESTOS-ST14-3/2/06	030606846-0013	West Face - South end at corner (scaffolding level)	3/2/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/6/06	< 13.00	No	No	
ASBESTOS-ST15-3/2/06	030606628-0010	South Face - East end at corner (scaffolding level)	3/2/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/3/06	< 13.00	No	No	
ASBESTOS-ST16-3/2/06	030606628-0011	East Face - North end at corner (scaffolding level)	3/2/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/3/06	< 13.00	No	No	
ASBESTOS-ST17-3/2/06	030606628-0012	North Face - West end at corner (scaffolding level)	3/2/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/3/06	< 13.00	No	No	