

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-3/10/08	030806425-0001	Southwest Area (sidewalk bridge level)	3/10/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/11/08	< 13.00	No	No	
ASBESTOS-ST2-3/10/08	030806425-0002	Southeast Area (sidewalk bridge level)	3/10/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/11/08	< 13.00	No	No	
ASBESTOS-ST4-3/10/08	030806425-0003	Northwest Area (street-level)	3/10/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/11/08	< 13.00	No	No	
ASBESTOS-ST5-3/10/08	030806425-0004	Firehouse #10 (roof level)	3/10/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/11/08	< 13.00	No	No	
ASBESTOS-ST10-3/10/08	030806425-0005	North Side Sidewalk Bridge	3/10/08	1	3.130	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/11/08	< 15.00	No	No	
ASBESTOS-ST11-3/10/08	030806425-0006	90 Trinity Place (roof level)	3/10/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/11/08	< 13.00	No	No	
ASBESTOS-ST12-3/10/08	030806425-0007	110 Greenwich Street (roof level)	3/10/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/11/08	< 15.00	No	No	
ASBESTOS-ST13-3/10/08	030806425-0008	Marriott Hotel, 38th Floor (roof level)	3/10/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/11/08	< 13.00	No	No	
ASBESTOS-ST14-3/10/08	030806425-0009	West Face - South end at corner (scaffolding level)	3/10/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/11/08	< 15.00	No	No	
ASBESTOS-ST15-3/10/08	030806425-0010	South Face - East end at corner (scaffolding level)	3/10/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/11/08	< 13.00	No	No	
ASBESTOS-ST16-3/10/08	030806425-0011	East Face - North end at corner (scaffolding level)	3/10/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/11/08	< 13.00	No	No	
ASBESTOS-ST17-3/10/08	030806425-0012	North Face - West end at corner (scaffolding level)	3/10/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/11/08	< 13.00	No	No	
ASBESTOS-ST1-3/11/08	030806575-0001	Southwest Area (sidewalk bridge level)	3/11/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/12/08	< 13.00	No	No	
ASBESTOS-ST2-3/11/08	030806575-0002	Southeast Area (sidewalk bridge level)	3/11/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/12/08	< 13.00	No	No	
ASBESTOS-ST4-3/11/08	030806575-0003	Northwest Area (street-level)	3/11/08	1	2.910	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/12/08	< 13.00	No	No	
ASBESTOS-ST5-3/11/08	030806575-0004	Firehouse #10 (roof level)	3/11/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/12/08	< 13.00	No	No	
ASBESTOS-ST10-3/11/08	030806575-0005	North Side Sidewalk Bridge	3/11/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/12/08	< 13.00	No	No	
ASBESTOS-ST11-3/11/08	030806575-0006	90 Trinity Place (roof level)	3/11/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/12/08	< 13.00	No	No	
ASBESTOS-ST12-3/11/08	030806575-0007	110 Greenwich Street (roof level)	3/11/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/12/08	< 13.00	No	No	
ASBESTOS-ST13-3/11/08	030806575-0008	Marriott Hotel, 38th Floor (roof level)	3/11/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/12/08	< 13.00	No	No	
ASBESTOS-ST14-3/11/08	030806575-0009	West Face - South end at corner (scaffolding level)	3/11/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/12/08	< 13.00	No	No	
ASBESTOS-ST15-3/11/08	030806575-0010	South Face - East end at corner (scaffolding level)	3/11/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/12/08	< 13.00	No	No	
ASBESTOS-ST16-3/11/08	030806575-0011	East Face - North end at corner (scaffolding level)	3/11/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/12/08	< 13.00	No	No	
ASBESTOS-ST17-3/11/08	030806575-0012	North Face - West end at corner (scaffolding level)	3/11/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/12/08	< 13.00	No	No	