

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-3/12/07	030707670-0001	Southwest Area (sidewalk bridge level)	3/12/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/13/07	< 13.00	No	No	
ASBESTOS-ST2-3/12/07	030707670-0002	Southeast Area (sidewalk bridge level)	3/12/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/13/07	< 13.00	No	No	
ASBESTOS-ST4-3/12/07	030707670-0003	Northwest Area (street-level)	3/12/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/13/07	< 13.00	No	No	
ASBESTOS-ST5-3/12/07	030707670-0004	Firehouse #10 (roof level)	3/12/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/13/07	< 13.00	No	No	
ASBESTOS-ST10-3/12/07	030707670-0005	North Side Sidewalk Bridge	3/12/07	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/13/07	< 13.00	No	No	
ASBESTOS-ST11-3/12/07	030707670-0006	90 Trinity Place (roof level)	3/12/07	1	2.890	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/13/07	< 13.00	No	No	
ASBESTOS-ST12-3/12/07	030707670-0007	110 Greenwich Street (roof level)	3/12/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/13/07	< 13.00	No	No	
ASBESTOS-ST13-3-12/07	030707670-0008	Marriott Hotel, 38th Floor (roof level)	3/12/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/13/07	< 13.00	No	No	
ASBESTOS-ST1-3/13/07	030707811-0001	Southwest Area (sidewalk bridge level)	3/13/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/14/07	< 13.00	No	No	
ASBESTOS-ST2-3/13/07	030707811-0002	Southeast Area (sidewalk bridge level)	3/13/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/14/07	< 13.00	No	No	
ASBESTOS-ST4-3/13/07	030707811-0003	Northwest Area (street-level)	3/13/07	1	3.190	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/14/07	< 13.00	No	No	
ASBESTOS-ST5-3/13/07	030707811-0004	Firehouse #10 (roof level)	3/13/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/14/07	< 13.00	No	No	
ASBESTOS-ST10-3/13/07	030707811-0005	North Side Sidewalk Bridge	3/13/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/14/07	< 13.00	No	No	
ASBESTOS-ST11-3-13/07	030707811-0006	90 Trinity Place (roof level)	3/13/07	1	3.130	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/14/07	< 13.00	No	No	
ASBESTOS-ST12-3/13/07	030707811-0007	110 Greenwich Street (roof level)	3/13/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/14/07	< 13.00	No	No	
ASBESTOS-ST13-3/13/07	030707811-0008	Marriott Hotel, 38th Floor (roof level)	3/13/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/14/07	< 13.00	No	No	
ASBESTOS-ST14-3/13/07	030707811-0009	West Face - South end at corner (scaffolding level)	3/13/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/14/07	< 13.00	No	No	
ASBESTOS-ST15-3/13/07	030707811-0010	South Face - East end at corner (scaffolding level)	3/13/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/14/07	< 13.00	No	No	
ASBESTOS-ST16-3/13/07	030707811-0011	East Face - North end at corner (scaffolding level)	3/13/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/14/07	< 13.00	No	No	
ASBESTOS-ST17-3/13/07	030707811-0012	North Face - West end at corner (scaffolding level)	3/13/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/14/07	< 13.00	No	No	

Note:
1. Asbestos samples at Station 14 (West Face - South end at corner [scaffolding level]), Station 15 (South Face - East end at corner [scaffolding level]), Station 16 (East Face - North end at corner [scaffolding level]), and Station 17 (North Face - West end at corner [scaffolding level]) on March 12, 2007 were not available for analysis on account of power failure.