

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)		Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
										NA				
										70				
<b>Target Air Quality Levels</b>														
<b>EPA Site Specific Trigger Levels</b>														
ASBESTOS-ST1-3/13/08	030806927-0001	Southwest Area (sidewalk bridge level)	3/13/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/14/08	< 13.00		No	No	
ASBESTOS-ST2-3/13/08	030806927-0002	Southeast Area (sidewalk bridge level)	3/13/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/14/08	< 13.00		No	No	
ASBESTOS-ST4-3/13/08	030806927-0003	Northwest Area (street-level)	3/13/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/14/08	< 13.00		No	No	
ASBESTOS-ST5-3/13/08	030806927-0004	Firehouse #10 (roof level)	3/13/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/14/08	< 13.00		No	No	
ASBESTOS-ST10-3/13/08	030806927-0005	North Side Sidewalk Bridge	3/13/08	1	3.200	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/14/08	< 13.00		No	No	
ASBESTOS-ST11-3/13/08	030806927-0006	90 Trinity Place (roof level)	3/13/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/14/08	< 13.00		No	No	
ASBESTOS-ST12-3/13/08	030806927-0007	110 Greenwich Street (roof level)	3/13/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/14/08	< 13.00		No	No	
ASBESTOS-ST13-3/13/08	030806927-0008	Marriott Hotel, 38th Floor (roof level)	3/13/08	1	3.170	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/14/08	< 13.00		No	No	
ASBESTOS-ST14-3/13/08	030806927-0009	West Face - South end at corner (scaffolding level)	3/13/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/14/08	< 13.00		No	No	
ASBESTOS-ST15-3/13/08	030806927-0010	South Face - East end at corner (scaffolding level)	3/13/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/14/08	< 13.00		No	No	
ASBESTOS-ST16-3/13/08	030806927-0011	East Face - North end at corner (scaffolding level)	3/13/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/14/08	< 13.00		No	No	
ASBESTOS-ST17-3/13/08	030806927-0012	North Face - West end at corner (scaffolding level)	3/13/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/14/08	< 13.00		No	No	
ASBESTOS-ST1-3/14/08	030807104-0001	Southwest Area (sidewalk bridge level)	3/14/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/15/08	< 13.00		No	No	
ASBESTOS-ST2-3/14/08	030807104-0002	Southeast Area (sidewalk bridge level)	3/14/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/15/08	< 13.00		No	No	
ASBESTOS-ST4-3/14/08	030807104-0003	Northwest Area (street-level)	3/14/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/15/08	< 13.00		No	No	
ASBESTOS-ST5-3/14/08	030807104-0004	Firehouse #10 (roof level)	3/14/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/15/08	< 13.00		No	No	
ASBESTOS-ST10-3/14/08	030807104-0005	North Side Sidewalk Bridge	3/14/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/15/08	< 13.00		No	No	
ASBESTOS-ST11-3/14/08	030807104-0006	90 Trinity Place (roof level)	3/14/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/15/08	< 13.00		No	No	
ASBESTOS-ST12-3/14/08	030807104-0007	110 Greenwich Street (roof level)	3/14/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/15/08	< 13.00		No	No	
ASBESTOS-ST13-3/14/08	030807104-0008	Marriott Hotel, 38th Floor (roof level)	3/14/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/15/08	< 13.00		No	No	
ASBESTOS-ST14-3/14/08	030807104-0009	West Face - South end at corner (scaffolding level)	3/14/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/15/08	< 13.00		No	No	
ASBESTOS-ST15-3/14/08	030807104-0010	South Face - East end at corner (scaffolding level)	3/14/08	1	3.160	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/15/08	< 13.00		No	No	
ASBESTOS-ST16-3/14/08	030807104-0011	East Face - North end at corner (scaffolding level)	3/14/08	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/15/08	< 13.00		No	No	
ASBESTOS-ST17-3/14/08	030807104-0012	North Face - West end at corner (scaffolding level)	3/14/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/15/08	< 13.00		No	No	
ASBESTOS-ST1-3/15/08	030807241-0001	Southwest Area (sidewalk bridge level)	3/15/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/08	< 13.00		No	No	
ASBESTOS-ST2-3/15/08	030807241-0002	Southeast Area (sidewalk bridge level)	3/15/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/08	< 13.00		No	No	
ASBESTOS-ST4-3/15/08	030807241-0003	Northwest Area (street-level)	3/15/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/08	< 13.00		No	No	
ASBESTOS-ST5-3/15/08	030807241-0004	Firehouse #10 (roof level)	3/15/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/08	< 13.00		No	No	
ASBESTOS-ST10-3/15/08	030807241-0005	North Side Sidewalk Bridge	3/15/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/08	< 13.00		No	No	
ASBESTOS-ST11-3/15/08	030807241-0006	90 Trinity Place (roof level)	3/15/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/08	< 13.00		No	No	
ASBESTOS-ST12-3/15/08	030807241-0007	110 Greenwich Street (roof level)	3/15/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/08	< 13.00		No	No	
ASBESTOS-ST13-3/15/08	030807241-0008	Marriott Hotel, 38th Floor (roof level)	3/15/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/08	< 13.00		No	No	
ASBESTOS-ST14-3/15/08	030807241-0009	West Face - South end at corner (scaffolding level)	3/15/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/08	< 13.00		No	No	
ASBESTOS-ST15-3/15/08	030807241-0010	South Face - East end at corner (scaffolding level)	3/15/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/08	< 13.00		No	No	
ASBESTOS-ST16-3/15/08	030807241-0011	East Face - North end at corner (scaffolding level)	3/15/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/08	< 13.00		No	No	
ASBESTOS-ST17-3/15/08	030807241-0012	North Face - West end at corner (scaffolding level)	3/15/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/08	< 13.00		No	No	
ASBESTOS-ST1-3/16/08	030807240-0001	Southwest Area (sidewalk bridge level)	3/16/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/08	< 13.00		No	No	
ASBESTOS-ST2-3/16/08	030807240-0002	Southeast Area (sidewalk bridge level)	3/16/08	1	3.130	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/08	< 15.00		No	No	
ASBESTOS-ST4-3/16/08	030807240-0003	Northwest Area (street-level)	3/16/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/08	< 15.00		No	No	
ASBESTOS-ST5-3/16/08	030807240-0004	Firehouse #10 (roof level)	3/16/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/08	< 15.00		No	No	
ASBESTOS-ST10-3/16/08	030807240-0005	North Side Sidewalk Bridge	3/16/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/08	< 13.00		No	No	
ASBESTOS-ST11-3/16/08	030807240-0006	90 Trinity Place (roof level)	3/16/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/08	< 13.00		No	No	
ASBESTOS-ST12-3/16/08	030807240-0007	110 Greenwich Street (roof level)	3/16/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/08	< 13.00		No	No	
ASBESTOS-ST13-3/16/08	030807240-0008	Marriott Hotel, 38th Floor (roof level)	3/16/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/08	< 13.00		No	No	
ASBESTOS-ST14-3/16/08	030807240-0009	West Face - South end at corner (scaffolding level)	3/16/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/08	< 13.00		No	No	
ASBESTOS-ST15-3/16/08	030807240-0010	South Face - East end at corner (scaffolding level)	3/16/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/08	< 13.00		No	No	
ASBESTOS-ST16-3/16/08	030807240-0011	East Face - North end at corner (scaffolding level)	3/16/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/08	< 13.00		No	No	
ASBESTOS-ST17-3/16/08	030807240-0012	North Face - West end at corner (scaffolding level)	3/16/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/08	< 13.00		No	No	