

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments	
Target Air Quality Levels											NA	Air Quality	Site Specific	Comments
EPA Site Specific Trigger Levels											70	Levels	Trigger Levels	
ASBESTOS-ST1-3/15/06	030608039-0001	Southwest Area (sidewalk bridge level)	3/15/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/16/06	< 13.00	No	No		
ASBESTOS-ST2-3/15/06	030608039-0002	Southeast Area (sidewalk bridge level)	3/15/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/16/06	< 13.00	No	No		
ASBESTOS-ST4-3/15/06	030608039-0003	Northwest Area (street-level)	3/15/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/16/06	< 13.00	No	No		
ASBESTOS-ST5-3/15/06	030608039-0004	Firehouse #10 (roof level)	3/15/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/16/06	< 13.00	No	No		
ASBESTOS-ST10-3/15/06	030608039-0005	North Side Sidewalk Bridge	3/15/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/16/06	< 13.00	No	No		
ASBESTOS-ST100-3/15/06	030608039-0013	Station 10 Field Duplicate	3/15/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/16/06	< 13.00	No	No		
ASBESTOS-ST11-3/15/06	030608039-0006	90 Trinity Place (roof level)	3/15/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/16/06	< 13.00	No	No		
ASBESTOS-ST12-3/15/06	030608039-0007	110 Greenwich Street (roof level)	3/15/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/16/06	< 13.00	No	No		
ASBESTOS-ST13-3/15/06	030608039-0008	Marriott Hotel, 38th Floor (roof level)	3/15/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/16/06	< 13.00	No	No		
ASBESTOS-ST14-3/15/06	030608039-0009	West Face - South end at corner (scaffolding level)	3/15/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/16/06	< 13.00	No	No		
ASBESTOS-ST15-3/15/06	030608039-0010	South Face - East end at corner (scaffolding level)	3/15/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/16/06	< 13.00	No	No		
ASBESTOS-ST16-3/15/06	030608039-0011	East Face - North end at corner (scaffolding level)	3/15/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/16/06	< 13.00	No	No		
ASBESTOS-ST17-3/15/06	030608039-0012	North Face - West end at corner (scaffolding level)	3/15/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/16/06	< 13.00	No	No		
ASBESTOS-ST1-3/16/06	030608206-0001	Southwest Area (sidewalk bridge level)	3/16/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/06	< 13.00	No	No		
ASBESTOS-ST2-3/16/06	030608206-0002	Southeast Area (sidewalk bridge level)	3/16/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/06	< 13.00	No	No		
ASBESTOS-ST4-3/16/06	030608206-0003	Northwest Area (street-level)	3/16/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/06	< 13.00	No	No		
ASBESTOS-ST5-3/16/06	030608206-0004	Firehouse #10 (roof level)	3/16/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/06	< 13.00	No	No		
ASBESTOS-ST10-3/16/06	030608206-0005	North Side Sidewalk Bridge	3/16/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/06	< 13.00	No	No		
ASBESTOS-ST100-3/16/06	030608206-0013	Station 10 Field Duplicate	3/16/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/06	< 13.00	No	No		
ASBESTOS-ST11-3/16/06	030608206-0006	90 Trinity Place (roof level)	3/16/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/06	< 13.00	No	No		
ASBESTOS-ST12-3/16/06	030608206-0007	110 Greenwich Street (roof level)	3/16/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/06	< 13.00	No	No		
ASBESTOS-ST13-3/16/06	030608206-0008	Marriott Hotel, 38th Floor (roof level)	3/16/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/06	< 13.00	No	No		
ASBESTOS-ST14-3/16/06	030608206-0009	West Face - South end at corner (scaffolding level)	3/16/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/06	< 13.00	No	No		
ASBESTOS-ST15-3/16/06	030608206-0010	South Face - East end at corner (scaffolding level)	3/16/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/06	< 13.00	No	No		
ASBESTOS-ST16-3/16/06	030608206-0011	East Face - North end at corner (scaffolding level)	3/16/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/06	< 13.00	No	No		
ASBESTOS-ST17-3/16/06	030608206-0012	North Face - West end at corner (scaffolding level)	3/16/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/17/06	< 13.00	No	No		