

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
										NA	Air Quality Levels	Site Specific Trigger Levels	
										70			
										Target Air Quality Levels			
										EPA Site Specific Trigger Levels			
ASBESTOS-ST1-3/21/09	030907484-0001	Southwest Area (sidewalk bridge level)	3/21/09	1	2.930	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/23/09	< 13.00	No	No	
ASBESTOS-ST2-3/21/09	030907484-0002	Southeast Area (sidewalk bridge level)	3/21/09	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/23/09	< 15.00	No	No	
ASBESTOS-ST4-3/21/09	030907484-0003	Northwest Area (street-level)	3/21/09	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/23/09	< 13.00	No	No	
ASBESTOS-ST5-3/21/09	030907484-0004	Firehouse #10 (roof level)	3/21/09	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/23/09	< 13.00	No	No	
ASBESTOS-ST10-3/21/09	030907484-0005	North Side Sidewalk Bridge	3/21/09	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/23/09	< 15.00	No	No	
ASBESTOS-ST11-3/21/09	030907484-0006	90 Trinity Place (roof level)	3/21/09	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/23/09	< 13.00	No	No	
ASBESTOS-ST12-3/21/09	030907484-0007	110 Greenwich Street (roof level)	3/21/09	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/23/09	< 13.00	No	No	
ASBESTOS-ST13-3/21/09	030907484-0008	Marriott Hotel, 38th Floor (roof level)	3/21/09	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/23/09	< 13.00	No	No	
ASBESTOS-ST14-3/21/09	030907484-0009	West Face - South end at corner (scaffolding level)	3/21/09	1	3.180	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/23/09	< 13.00	No	No	
ASBESTOS-ST15-3/21/09	030907484-0010	South Face - East end at corner (scaffolding level)	3/21/09	1	3.200	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/23/09	< 15.00	No	No	
ASBESTOS-ST16-3/21/09	030907484-0011	East Face - North end at corner (scaffolding level)	3/21/09	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/23/09	< 15.00	No	No	
ASBESTOS-ST17-3/21/09	030907484-0012	North Face - West end at corner (scaffolding level)	3/21/09	1	3.200	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/23/09	< 15.00	No	No	
ASBESTOS-ST1-3/22/09	030907488-0001	Southwest Area (sidewalk bridge level)	3/22/09	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/23/09	< 13.00	No	No	
ASBESTOS-ST2-3/22/09	030907488-0002	Southeast Area (sidewalk bridge level)	3/22/09	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/23/09	< 15.00	No	No	
ASBESTOS-ST4-3/22/09	030907488-0003	Northwest Area (street-level)	3/22/09	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/23/09	< 13.00	No	No	
ASBESTOS-ST5-3/22/09	030907488-0004	Firehouse #10 (roof level)	3/22/09	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/23/09	< 13.00	No	No	
ASBESTOS-ST10-3/22/09	030907488-0005	North Side Sidewalk Bridge	3/22/09	1	3.300	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/23/09	< 15.00	No	No	
ASBESTOS-ST11-3/22/09	030907488-0006	90 Trinity Place (roof level)	3/22/09	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/23/09	< 13.00	No	No	
ASBESTOS-ST12-3/22/09	030907488-0007	110 Greenwich Street (roof level)	3/22/09	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/23/09	< 13.00	No	No	
ASBESTOS-ST13-3/22/09	030907488-0008	Marriott Hotel, 38th Floor (roof level)	3/22/09	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/23/09	< 13.00	No	No	
ASBESTOS-ST14-3/22/09	030907488-0009	West Face - South end at corner (scaffolding level)	3/22/09	1	3.190	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/23/09	< 15.00	No	No	
ASBESTOS-ST15-3/22/09	030907488-0010	South Face - East end at corner (scaffolding level)	3/22/09	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/23/09	< 15.00	No	No	
ASBESTOS-ST16-3/22/09	030907488-0011	East Face - North end at corner (scaffolding level)	3/22/09	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/23/09	< 13.00	No	No	
ASBESTOS-ST17-3/22/09	030907488-0012	North Face - West end at corner (scaffolding level)	3/22/09	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/23/09	< 15.00	No	No	