

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-3/25/08	030808405-0001	Southwest Area (sidewalk bridge level)	3/25/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/26/08	< 15.00	No	No	
ASBESTOS-ST2-3/25/08	030808405-0002	Southeast Area (sidewalk bridge level)	3/25/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/26/08	< 13.00	No	No	
ASBESTOS-ST4-3/25/08	030808405-0003	Northwest Area (street-level)	3/25/08	1	3.310	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/26/08	< 15.00	No	No	
ASBESTOS-ST5-3/25/08	030808405-0004	Firehouse #10 (roof level)	3/25/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/26/08	< 15.00	No	No	
ASBESTOS-ST10-3/25/08	030808405-0005	North Side Sidewalk Bridge	3/25/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/26/08	< 15.00	No	No	
ASBESTOS-ST11-3/25/08	030808405-0006	90 Trinity Place (roof level)	3/25/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/26/08	< 13.00	No	No	
ASBESTOS-ST12-3/25/08	030808405-0007	110 Greenwich Street (roof level)	3/25/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/26/08	< 15.00	No	No	
ASBESTOS-ST13-3/25/08	030808405-0008	Marriott Hotel, 38th Floor (roof level)	3/25/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/26/08	< 13.00	No	No	
ASBESTOS-ST14-3/25/08	030808405-0009	West Face - South end at corner (scaffolding level)	3/25/08	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/26/08	< 13.00	No	No	
ASBESTOS-ST15-3/25/08	030808405-0010	South Face - East end at corner (scaffolding level)	3/25/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/26/08	< 13.00	No	No	
ASBESTOS-ST16-3/25/08	030808405-0011	East Face - North end at corner (scaffolding level)	3/25/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/26/08	< 13.00	No	No	
ASBESTOS-ST17-3/25/08	030808405-0012	North Face - West end at corner (scaffolding level)	3/25/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/26/08	< 13.00	No	No	
ASBESTOS-ST1-3/26/08	030808532-0001	Southwest Area (sidewalk bridge level)	3/26/08	1	3.210	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/27/08	< 15.00	No	No	
ASBESTOS-ST2-3/26/08	030808532-0002	Southeast Area (sidewalk bridge level)	3/26/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/27/08	< 13.00	No	No	
ASBESTOS-ST4-3/26/08	030808532-0003	Northwest Area (street-level)	3/26/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/27/08	13.00	No	No	
ASBESTOS-ST5-3/26/08	030808532-0004	Firehouse #10 (roof level)	3/26/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/27/08	< 13.00	No	No	
ASBESTOS-ST10-3/26/08	030808532-0005	North Side Sidewalk Bridge	3/26/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/27/08	< 13.00	No	No	
ASBESTOS-ST11-3/26/08	030808532-0006	90 Trinity Place (roof level)	3/26/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/27/08	< 15.00	No	No	
ASBESTOS-ST12-3/26/08	030808532-0007	110 Greenwich Street (roof level)	3/26/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/27/08	< 13.00	No	No	
ASBESTOS-ST13-3/26/08	030808532-0008	Marriott Hotel, 38th Floor (roof level)	3/26/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/27/08	< 15.00	No	No	
ASBESTOS-ST14-3/26/08	030808532-0009	West Face - South end at corner (scaffolding level)	3/26/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/27/08	< 15.00	No	No	
ASBESTOS-ST15-3/26/08	030808532-0010	South Face - East end at corner (scaffolding level)	3/26/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/27/08	< 13.00	No	No	
ASBESTOS-ST16-3/26/08	030808532-0011	East Face - North end at corner (scaffolding level)	3/26/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/27/08	< 13.00	No	No	
ASBESTOS-ST17-3/26/08	030808532-0012	North Face - West end at corner (scaffolding level)	3/26/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/27/08	< 13.00	No	No	