

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels											Air Quality Levels	Site Specific Trigger Levels	Comments
EPA Site Specific Trigger Levels													
											NA		
											70		
ASBESTOS-ST1-4/13/09	030909442-0001	Southwest Area (sidewalk bridge level)	4/13/09	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/14/09	< 13.00	No	No	
ASBESTOS-ST2-4/13/09	030909442-0002	Southeast Area (sidewalk bridge level)	4/13/09	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/14/09	< 13.00	No	No	
ASBESTOS-ST4-4/13/09	030909442-0003	Northwest Area (street-level)	4/13/09	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/14/09	< 13.00	No	No	
ASBESTOS-ST5-4/13/09	030909442-0004	Firehouse #10 (roof level)	4/13/09	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/14/09	< 13.00	No	No	
ASBESTOS-ST10-4/13/09	030909442-0005	North Side Sidewalk Bridge	4/13/09	1	3.190	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/14/09	< 13.00	No	No	
ASBESTOS-ST11-4/13/09	030909442-0006	90 Trinity Place (roof level)	4/13/09	1	3.160	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/14/09	< 13.00	No	No	
ASBESTOS-ST12-4/13/09	030909442-0007	110 Greenwich Street (roof level)	4/13/09	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/14/09	< 13.00	No	No	
ASBESTOS-ST13-4/13/09	030909442-0008	Marriott Hotel, 38th Floor (roof level)	4/13/09	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/14/09	< 13.00	No	No	
ASBESTOS-ST14-4/13/09	030909442-0009	West Face - South end at corner (scaffolding level)	4/13/09	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/14/09	< 13.00	No	No	
ASBESTOS-ST15-4/13/09	030909442-0010	South Face - East end at corner (scaffolding level)	4/13/09	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/14/09	< 13.00	No	No	
ASBESTOS-ST16-4/13/09	030909442-0011	East Face - North end at corner (scaffolding level)	4/13/09	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/14/09	< 13.00	No	No	
ASBESTOS-ST17-4/13/09	030909442-0012	North Face - West end at corner (scaffolding level)	4/13/09	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/14/09	< 13.00	No	No	
ASBESTOS-ST1-4/14/09	030909609-0001	Southwest Area (sidewalk bridge level)	4/14/09	1	2.860	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/15/09	< 13.00	No	No	Note 1
ASBESTOS-ST2-4/14/09	030909609-0002	Southeast Area (sidewalk bridge level)	4/14/09	1	2.860	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/15/09	< 13.00	No	No	Note 2
ASBESTOS-ST4-4/14/09	030909609-0003	Northwest Area (street-level)	4/14/09	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/15/09	< 13.00	No	No	
ASBESTOS-ST5-4/14/09	030909609-0004	Firehouse #10 (roof level)	4/14/09	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/15/09	< 13.00	No	No	
ASBESTOS-ST10-4/14/09	030909609-0005	North Side Sidewalk Bridge	4/14/09	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/15/09	< 13.00	No	No	
ASBESTOS-ST11-4/14/09	030909609-0006	90 Trinity Place (roof level)	4/14/09	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/15/09	< 13.00	No	No	
ASBESTOS-ST12-4/14/09	030909609-0007	110 Greenwich Street (roof level)	4/14/09	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/15/09	< 13.00	No	No	
ASBESTOS-ST13-4/14/09	030909609-0008	Marriott Hotel, 38th Floor (roof level)	4/14/09	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/15/09	< 13.00	No	No	
ASBESTOS-ST14-4/14/09	030909667-0001	West Face - South end at corner (scaffolding level)	4/14/09	1	4.650	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/16/09	< 13.00	No	No	Note3
ASBESTOS-ST15-4/14/09	030909667-0002	South Face - East end at corner (scaffolding level)	4/14/09	1	4.920	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/16/09	< 13.00	No	No	Note 3
ASBESTOS-ST16-4/14/09	030909667-0003	East Face - North end at corner (scaffolding level)	4/14/09	1	4.610	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/16/09	< 13.00	No	No	Note 3
ASBESTOS-ST17-4/14/09	030909667-0004	North Face - West end at corner (scaffolding level)	4/14/09	1	4.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/16/09	< 13.00	No	No	Note 3

Note:

1. The asbestos sample from Station 1 (Southwest Area [sidewalk bridge level]) on April 14, 2009 experienced a 90 minute power outage.
2. The asbestos sample from Station 2 (Southeast Area [sidewalk bridge level]) on April 14, 2009 experienced an 80 minute power outage.
3. The asbestos samples from Station 14 (West Face - South end at corner [scaffolding level]), Station 15 (South Face - East end at corner [scaffolding level]), Station 16 (East Face - North end at corner [scaffolding level]), and Station 17 (North Face - West end at corner [scaffolding level]) on April 14, 2009 were not recovered until April 16, 2009 due to a power failure on April 15, 2009. Therefore the samples represent a 2220 minute sampling time composite from April 14 to April 15, 2009.