

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments	
Target Air Quality Levels											NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels											70			
ASBESTOS-ST1-4/18/07	030711957-0001	Southwest Area (sidewalk bridge level)	4/18/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/19/07	< 13.00	No	No		
ASBESTOS-ST2-4/18/07	030711957-0002	Southeast Area (sidewalk bridge level)	4/18/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/19/07	< 13.00	No	No		
ASBESTOS-ST4-4/18/07	030711957-0003	Northwest Area (street-level)	4/18/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/19/07	< 13.00	No	No		
ASBESTOS-ST5-4/18/07	030711957-0004	Firehouse #10 (roof level)	4/18/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/19/07	< 13.00	No	No		
ASBESTOS-ST10-4/18/07	030711957-0005	North Side Sidewalk Bridge	4/18/07	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/19/07	< 13.00	No	No		
ASBESTOS-ST11-4/18/07	030711957-0006	90 Trinity Place (roof level)	4/18/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/19/07	< 13.00	No	No		
ASBESTOS-ST12-4/18/07	030711957-0007	110 Greenwich Street (roof level)	4/18/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/19/07	< 13.00	No	No		
ASBESTOS-ST13-4/18/07	030711957-0008	Marriott Hotel, 38th Floor (roof level)	4/18/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/19/07	< 13.00	No	No		
ASBESTOS-ST14-4/18/07	030711957-0009	West Face - South end at corner (scaffolding level)	4/18/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/19/07	< 13.00	No	No		
ASBESTOS-ST15-4/18/07	030711957-0010	South Face - East end at corner (scaffolding level)	4/18/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/19/07	< 13.00	No	No		
ASBESTOS-ST16-4/18/07	030711957-0011	East Face - North end at corner (scaffolding level)	4/18/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/19/07	< 13.00	No	No		
ASBESTOS-ST17-4/18/07	030711957-0012	North Face - West end at corner (scaffolding level)	4/18/07	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/19/07	< 13.00	No	No		
ASBESTOS-ST1-4/19/07	030712086-0001	Southwest Area (sidewalk bridge level)	4/19/07	1	3.230	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/20/07	< 13.00	No	No		
ASBESTOS-ST2-4/19/07	030712086-0002	Southeast Area (sidewalk bridge level)	4/19/07	1	3.210	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/20/07	< 13.00	No	No		
ASBESTOS-ST4-4/19/07	030712086-0003	Northwest Area (street-level)	4/19/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/20/07	< 13.00	No	No		
ASBESTOS-ST5-4/19/07	030712086-0004	Firehouse #10 (roof level)	4/19/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/20/07	< 13.00	No	No		
ASBESTOS-ST10-4/19/07	030712086-0005	North Side Sidewalk Bridge	4/19/07	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/20/07	< 13.00	No	No		
ASBESTOS-ST100-4/19/07	030712086-0013	Station 10 Field Duplicate	4/19/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/20/07	< 13.00	No	No		
ASBESTOS-ST11-4/19/07	030712086-0006	90 Trinity Place (roof level)	4/19/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/20/07	< 13.00	No	No		
ASBESTOS-ST12-4/19/07	030712086-0007	110 Greenwich Street (roof level)	4/19/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/20/07	< 13.00	No	No		
ASBESTOS-ST13-4/19/07	030712086-0008	Marriott Hotel, 38th Floor (roof level)	4/19/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/20/07	< 13.00	No	No		
ASBESTOS-ST14-4/19/07	030712086-0009	West Face - South end at corner (scaffolding level)	4/19/07	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/20/07	< 13.00	No	No		
ASBESTOS-ST15-4/19/07	030712086-0010	South Face - East end at corner (scaffolding level)	4/19/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/20/07	< 13.00	No	No		
ASBESTOS-ST16-4/19/07	030712086-0011	East Face - North end at corner (scaffolding level)	4/19/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/20/07	< 13.00	No	No		
ASBESTOS-ST17-4/19/07	030712086-0012	North Face - West end at corner (scaffolding level)	4/19/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/20/07	< 13.00	No	No		