

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments	
Target Air Quality Levels											NA	Air Quality	Site Specific	Comments
EPA Site Specific Trigger Levels											70	Levels	Trigger Levels	
ASBESTOS-ST1-4/28/06	030613054-0001	Southwest Area (sidewalk bridge level)	4/28/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST2-4/28/06	030613054-0002	Southeast Area (sidewalk bridge level)	4/28/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST4-4/28/06	030613054-0003	Northwest Area (street-level)	4/28/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST5-4/28/06	030613054-0004	Firehouse #10 (roof level)	4/28/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST10-4/28/06	030613054-0005	North Side Sidewalk Bridge	4/28/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST100-4/28/06	030613054-0013	Station 10 Field Duplicate	4/28/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST11-4/28/06	030613054-0006	90 Trinity Place (roof level)	4/28/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST12-4/28/06	030613054-0007	110 Greenwich Street (roof level)	4/28/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST13-4/28/06	030613054-0008	Marriott Hotel, 38th Floor (roof level)	4/28/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST14-4/28/06	030613054-0009	West Face - South end at corner (scaffolding level)	4/28/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST15-4/28/06	030613054-0010	South Face - East end at corner (scaffolding level)	4/28/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST16-4/28/06	030613054-0011	East Face - North end at corner (scaffolding level)	4/28/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST17-4/28/06	030613054-0012	North Face - West end at corner (scaffolding level)	4/28/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST1-4/29/06	030613059-0001	Southwest Area (sidewalk bridge level)	4/29/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST2-4/29/06	030613059-0002	Southeast Area (sidewalk bridge level)	4/29/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST4-4/29/06	030613059-0003	Northwest Area (street-level)	4/29/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST5-4/29/06	030613059-0004	Firehouse #10 (roof level)	4/29/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST10-4/29/06	030613059-0005	North Side Sidewalk Bridge	4/29/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST11-4/29/06	030613059-0006	90 Trinity Place (roof level)	4/29/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST12-4/29/06	030613059-0007	110 Greenwich Street (roof level)	4/29/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST13-4/29/06	030613059-0008	Marriott Hotel, 38th Floor (roof level)	4/29/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST14-4/29/06	030613059-0009	West Face - South end at corner (scaffolding level)	4/29/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST15-4/29/06	030613059-0010	South Face - East end at corner (scaffolding level)	4/29/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST16-4/29/06	030613059-0011	East Face - North end at corner (scaffolding level)	4/29/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST17-4/29/06	030613059-0012	North Face - West end at corner (scaffolding level)	4/29/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST1-4/30/06	030613056-0001	Southwest Area (sidewalk bridge level)	4/30/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST2-4/30/06	030613056-0002	Southeast Area (sidewalk bridge level)	4/30/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST4-4/30/06	030613056-0003	Northwest Area (street-level)	4/30/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST5-4/30/06	030613056-0004	Firehouse #10 (roof level)	4/30/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST10-4/30/06	030613056-0005	North Side Sidewalk Bridge	4/30/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST11-4/30/06	030613056-0006	90 Trinity Place (roof level)	4/30/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST12-4/30/06	030613056-0007	110 Greenwich Street (roof level)	4/30/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST13-4/30/06	030613056-0008	Marriott Hotel, 38th Floor (roof level)	4/30/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST14-4/30/06	030613056-0009	West Face - South end at corner (scaffolding level)	4/30/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST15-4/30/06	030613056-0010	South Face - East end at corner (scaffolding level)	4/30/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST16-4/30/06	030613056-0011	East Face - North end at corner (scaffolding level)	4/30/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		
ASBESTOS-ST17-4/30/06	030613056-0012	North Face - West end at corner (scaffolding level)	4/30/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/1/06	< 13.00	No	No		