

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
										NA	Air Quality Levels	Site Specific Trigger Levels	
										70			
										Target Air Quality Levels			
										EPA Site Specific Trigger Levels			
ASBESTOS-ST1-5/2/09	030911244-0001	Southwest Area (sidewalk bridge level)	5/2/09	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/4/09	< 15.00	No	No	
ASBESTOS-ST2-5/2/09	030911244-0002	Southeast Area (sidewalk bridge level)	5/2/09	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/4/09	< 13.00	No	No	
ASBESTOS-ST4-5/2/09	030911244-0003	Northwest Area (street-level)	5/2/09	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/4/09	< 13.00	No	No	
ASBESTOS-ST5-5/2/09	030911244-0004	Firehouse #10 (roof level)	5/2/09	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/4/09	< 13.00	No	No	
ASBESTOS-ST10-5/2/09	030911244-0005	North Side Sidewalk Bridge	5/2/09	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/4/09	< 13.00	No	No	
ASBESTOS-ST11-5/2/09	030911244-0006	90 Trinity Place (roof level)	5/2/09	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/4/09	< 13.00	No	No	
ASBESTOS-ST12-5/2/09	030911244-0007	110 Greenwich Street (roof level)	5/2/09	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/4/09	< 13.00	No	No	
ASBESTOS-ST13-5/2/09	030911244-0008	Marriott Hotel, 38th Floor (roof level)	5/2/09	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/4/09	< 13.00	No	No	
ASBESTOS-ST14-5/2/09	030911244-0009	West Face - South end at corner (scaffolding level)	5/2/09	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/4/09	< 13.00	No	No	
ASBESTOS-ST15-5/2/09	030911244-0010	South Face - East end at corner (scaffolding level)	5/2/09	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/4/09	< 13.00	No	No	
ASBESTOS-ST16-5/2/09	030911244-0011	East Face - North end at corner (scaffolding level)	5/2/09	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/4/09	< 15.00	No	No	
ASBESTOS-ST17-5/2/09	030911244-0012	North Face - West end at corner (scaffolding level)	5/2/09	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/4/09	< 13.00	No	No	
ASBESTOS-ST1-5/3/09	030911245-0001	Southwest Area (sidewalk bridge level)	5/3/09	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/4/09	< 13.00	No	No	
ASBESTOS-ST2-5/3/09	030911245-0002	Southeast Area (sidewalk bridge level)	5/3/09	1	3.200	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/4/09	< 15.00	No	No	
ASBESTOS-ST4-5/3/09	030911245-0003	Northwest Area (street-level)	5/3/09	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/4/09	< 15.00	No	No	
ASBESTOS-ST5-5/3/09	030911245-0004	Firehouse #10 (roof level)	5/3/09	1	3.170	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/4/09	< 15.00	No	No	
ASBESTOS-ST10-5/3/09	030911245-0005	North Side Sidewalk Bridge	5/3/09	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/4/09	< 13.00	No	No	
ASBESTOS-ST11-5/3/09	030911245-0006	90 Trinity Place (roof level)	5/3/09	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/4/09	< 15.00	No	No	
ASBESTOS-ST12-5/3/09	030911245-0007	110 Greenwich Street (roof level)	5/3/09	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/4/09	< 15.00	No	No	
ASBESTOS-ST13-5/3/09	030911245-0008	Marriott Hotel, 38th Floor (roof level)	5/3/09	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/4/09	< 15.00	No	No	
ASBESTOS-ST14-5/3/09	030911245-0009	West Face - South end at corner (scaffolding level)	5/3/09	1	3.320	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/4/09	< 15.00	No	No	Note 1
ASBESTOS-ST15-5/3/09	030911245-0010	South Face - East end at corner (scaffolding level)	5/3/09	1	3.130	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/4/09	< 15.00	No	No	
ASBESTOS-ST16-5/3/09	030911245-0011	East Face - North end at corner (scaffolding level)	5/3/09	1	3.180	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/4/09	< 15.00	No	No	Note 1
ASBESTOS-ST17-5/3/09	030911245-0012	North Face - West end at corner (scaffolding level)	5/3/09	1	3.280	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/4/09	< 15.00	No	No	Note 1

Note:

- The asbestos samples from Station 14 (West Face - South end at corner [scaffolding level]), Station 16 (East Face - North end at corner [scaffolding level]), and Station 17 (North Face - West end at corner [scaffolding level]) on May 3, 2009 experienced a 130 minute power outage.