

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
										NA	Air Quality	Site Specific	
										70	Levels	Trigger Levels	
ASBESTOS-ST1-5/4/06	030613644-0001	Southwest Area (sidewalk bridge level)	5/4/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/5/06	< 13.00	No	No	
ASBESTOS-ST2-5/4/06	030613644-0002	Southeast Area (sidewalk bridge level)	5/4/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/5/06	< 13.00	No	No	
ASBESTOS-ST4-5/4/06	030613644-0003	Northwest Area (street-level)	5/4/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/5/06	< 13.00	No	No	
ASBESTOS-ST5-5/4/06	030613644-0004	Firehouse #10 (roof level)	5/4/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/5/06	< 13.00	No	No	
ASBESTOS-ST10-5/4/06	030613644-0005	North Side Sidewalk Bridge	5/4/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/5/06	< 13.00	No	No	
ASBESTOS-ST11-5/4/06	030613644-0006	90 Trinity Place (roof level)	5/4/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/5/06	< 13.00	No	No	
ASBESTOS-ST12-5/4/06	030613644-0007	110 Greenwich Street (roof level)	5/4/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/5/06	< 13.00	No	No	
ASBESTOS-ST13-5/4/06	030613644-0008	Marriott Hotel, 38th Floor (roof level)	5/4/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/5/06	< 13.00	No	No	
ASBESTOS-ST14-5/4/06	030613644-0009	West Face - South end at corner (scaffolding level)	5/4/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/5/06	< 13.00	No	No	
ASBESTOS-ST15-5/4/06	030613644-0010	South Face - East end at corner (scaffolding level)	5/4/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/5/06	< 13.00	No	No	
ASBESTOS-ST16-5/4/06	030613644-0011	East Face - North end at corner (scaffolding level)	5/4/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/5/06	< 13.00	No	No	
ASBESTOS-ST17-5/4/06	030613644-0012	North Face - West end at corner (scaffolding level)	5/4/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/5/06	< 13.00	No	No	