

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-5/7/07	030714505-0001	Southwest Area (sidewalk bridge level)	5/7/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/8/07	< 13.00	No	No	
ASBESTOS-ST2-5/7/07	030714505-0002	Southeast Area (sidewalk bridge level)	5/7/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/8/07	< 13.00	No	No	
ASBESTOS-ST4-5/7/07	030714505-0003	Northwest Area (street-level)	5/7/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/8/07	< 15.00	No	No	
ASBESTOS-ST5-5/7/07	030714505-0004	Firehouse #10 (roof level)	5/7/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/8/07	< 13.00	No	No	
ASBESTOS-ST10-5/7/07	030714505-0005	North Side Sidewalk Bridge	5/7/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/8/07	< 15.00	No	No	
ASBESTOS-ST100-5/7/07	030714505-0013	Station 10 Field Duplicate	5/7/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/8/07	< 13.00	No	No	
ASBESTOS-ST11-5/7/07	030714505-0006	90 Trinity Place (roof level)	5/7/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/8/07	< 15.00	No	No	
ASBESTOS-ST12-5/7/07	030714505-0007	110 Greenwich Street (roof level)	5/7/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/8/07	< 13.00	No	No	
ASBESTOS-ST13-5/7/07	030714505-0008	Marriott Hotel, 38th Floor (roof level)	5/7/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/8/07	< 13.00	No	No	
ASBESTOS-ST14-5/7/07	030714505-0009	West Face - South end at corner (scaffolding level)	5/7/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/8/07	< 13.00	No	No	
ASBESTOS-ST15-5/7/07	030714505-0010	South Face - East end at corner (scaffolding level)	5/7/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/8/07	< 13.00	No	No	
ASBESTOS-ST16-5/7/07	030714505-0011	East Face - North end at corner (scaffolding level)	5/7/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/8/07	< 15.00	No	No	
ASBESTOS-ST17-5/7/07	030714505-0012	North Face - West end at corner (scaffolding level)	5/7/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/8/07	< 13.00	No	No	
ASBESTOS-ST1-5/8/07	030714648-0001	Southwest Area (sidewalk bridge level)	5/8/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/9/07	< 13.00	No	No	
ASBESTOS-ST2-5/8/07	030714648-0002	Southeast Area (sidewalk bridge level)	5/8/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/9/07	< 13.00	No	No	
ASBESTOS-ST4-5/8/07	030714648-0003	Northwest Area (street-level)	5/8/07	1	3.180	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/9/07	< 13.00	No	No	
ASBESTOS-ST5-5/8/07	030714648-0004	Firehouse #10 (roof level)	5/8/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/9/07	< 13.00	No	No	
ASBESTOS-ST10-5/8/07	030714648-0005	North Side Sidewalk Bridge	5/8/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/9/07	< 13.00	No	No	
ASBESTOS-ST11-5/8/07	030714648-0006	90 Trinity Place (roof level)	5/8/07	1	3.130	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/9/07	< 13.00	No	No	
ASBESTOS-ST12-5/8/07	030714648-0007	110 Greenwich Street (roof level)	5/8/07	1	2.780	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/9/07	< 13.00	No	No	
ASBESTOS-ST13-5/8/07	030714648-0008	Marriott Hotel, 38th Floor (roof level)	5/8/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/9/07	< 13.00	No	No	
ASBESTOS-ST14-5/8/07	030714648-0009	West Face - South end at corner (scaffolding level)	5/8/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/9/07	< 13.00	No	No	
ASBESTOS-ST15-5/8/07	030714648-0010	South Face - East end at corner (scaffolding level)	5/8/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/9/07	< 13.00	No	No	
ASBESTOS-ST16-5/8/07	030714648-0011	East Face - North end at corner (scaffolding level)	5/8/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/9/07	< 13.00	No	No	
ASBESTOS-ST17-5/8/07	030714648-0012	North Face - West end at corner (scaffolding level)	5/8/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/9/07	< 13.00	No	No	