

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
										NA	Air Quality Levels	Site Specific Trigger Levels	
										70			
ASBESTOS-ST1-5/9/07	030714806-0001	Southwest Area (sidewalk bridge level)	5/9/07	1	3.160	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/10/07	< 13.00	No	No	
ASBESTOS-ST2-5/9/07	030714806-0002	Southeast Area (sidewalk bridge level)	5/9/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/10/07	< 13.00	No	No	
ASBESTOS-ST4-5/9/07	030714806-0003	Northwest Area (street-level)	5/9/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/10/07	< 13.00	No	No	
ASBESTOS-ST5-5/9/07	030714806-0004	Firehouse #10 (roof level)	5/9/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/10/07	< 13.00	No	No	
ASBESTOS-ST10-5/9/07	030714806-0005	North Side Sidewalk Bridge	5/9/07	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/10/07	< 13.00	No	No	
ASBESTOS-ST11-5/9/07	030714806-0006	90 Trinity Place (roof level)	5/9/07	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/10/07	< 13.00	No	No	
ASBESTOS-ST12-5/9/07	030714806-0007	110 Greenwich Street (roof level)	5/9/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/10/07	< 13.00	No	No	
ASBESTOS-ST13-5/9/07	030714806-0008	Marriott Hotel, 38th Floor (roof level)	5/9/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/10/07	< 13.00	No	No	
ASBESTOS-ST14-5/9/07	030714806-0009	West Face - South end at corner (scaffolding level)	5/9/07	1	2.920	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/10/07	< 13.00	No	No	
ASBESTOS-ST15-5/9/07	030714806-0010	South Face - East end at corner (scaffolding level)	5/9/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/10/07	< 13.00	No	No	
ASBESTOS-ST16-5/9/07	030714806-0011	East Face - North end at corner (scaffolding level)	5/9/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/10/07	< 13.00	No	No	
ASBESTOS-ST17-5/9/07	030714806-0012	North Face - West end at corner (scaffolding level)	5/9/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/10/07	< 13.00	No	No	