

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-5/10/08	030814420-0001	Southwest Area (sidewalk bridge level)	5/10/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/12/08	< 13.00	No	No	
ASBESTOS-ST2-5/10/08	030814420-0002	Southeast Area (sidewalk bridge level)	5/10/08	1	2.680	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/12/08	< 13.00	No	No	
ASBESTOS-ST4-5/10/08	030814420-0003	Northwest Area (street-level)	5/10/08	1	3.170	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/12/08	< 13.00	No	No	
ASBESTOS-ST5-5/10/08	030814420-0004	Firehouse #10 (roof level)	5/10/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/12/08	< 13.00	No	No	
ASBESTOS-ST10-5/10/08	030814420-0005	North Side Sidewalk Bridge	5/10/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/12/08	< 13.00	No	No	
ASBESTOS-ST11-5/10/08	030814420-0006	90 Trinity Place (roof level)	5/10/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/12/08	< 13.00	No	No	
ASBESTOS-ST12-5/10/08	030814420-0007	110 Greenwich Street (roof level)	5/10/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/12/08	< 13.00	No	No	
ASBESTOS-ST13-5/10/08	030814420-0008	Marriott Hotel, 38th Floor (roof level)	5/10/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/12/08	< 13.00	No	No	
ASBESTOS-ST14-5/10/08	030814420-0009	West Face - South end at corner (scaffolding level)	5/10/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/12/08	< 13.00	No	No	
ASBESTOS-ST15-5/10/08	030814420-0010	South Face - East end at corner (scaffolding level)	5/10/08	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/12/08	< 13.00	No	No	
ASBESTOS-ST16-5/10/08	030814420-0011	East Face - North end at corner (scaffolding level)	5/10/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/12/08	< 13.00	No	No	
ASBESTOS-ST17-5/10/08	030814420-0012	North Face - West end at corner (scaffolding level)	5/10/08	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/12/08	< 13.00	No	No	
ASBESTOS-ST1-5/11/08	030814466-0001	Southwest Area (sidewalk bridge level)	5/11/08	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/12/08	< 13.00	No	No	
ASBESTOS-ST2-5/11/08	030814466-0002	Southeast Area (sidewalk bridge level)	5/11/08	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/12/08	< 13.00	No	No	
ASBESTOS-ST4-5/11/08	030814466-0003	Northwest Area (street-level)	5/11/08	1	2.920	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/12/08	< 13.00	No	No	
ASBESTOS-ST5-5/11/08	030814466-0004	Firehouse #10 (roof level)	5/11/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/12/08	< 13.00	No	No	
ASBESTOS-ST10-5/11/08	030814466-0005	North Side Sidewalk Bridge	5/11/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/12/08	< 13.00	No	No	
ASBESTOS-ST11-5/11/08	030814466-0006	90 Trinity Place (roof level)	5/11/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/12/08	< 13.00	No	No	
ASBESTOS-ST12-5/11/08	030814466-0007	110 Greenwich Street (roof level)	5/11/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/12/08	< 13.00	No	No	
ASBESTOS-ST13-5/11/08	030814466-0008	Marriott Hotel, 38th Floor (roof level)	5/11/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/12/08	< 13.00	No	No	
ASBESTOS-ST14-5/11/08	030814466-0009	West Face - South end at corner (scaffolding level)	5/11/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/12/08	< 13.00	No	No	
ASBESTOS-ST15-5/11/08	030814466-0010	South Face - East end at corner (scaffolding level)	5/11/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/12/08	< 13.00	No	No	
ASBESTOS-ST16-5/11/08	030814466-0011	East Face - North end at corner (scaffolding level)	5/11/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/12/08	< 13.00	No	No	
ASBESTOS-ST17-5/11/08	030814466-0012	North Face - West end at corner (scaffolding level)	5/11/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/12/08	< 13.00	No	No	