

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-5/13/08	030814784-0001	Southwest Area (sidewalk bridge level)	5/13/08	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/14/08	< 13.00	No	No	
ASBESTOS-ST2-5/13/08	030814784-0002	Southeast Area (sidewalk bridge level)	5/13/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/14/08	< 13.00	No	No	
ASBESTOS-ST4-5/13/08	030814784-0003	Northwest Area (street-level)	5/13/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/14/08	< 13.00	No	No	
ASBESTOS-ST5-5/13/08	030814784-0004	Firehouse #10 (roof level)	5/13/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/14/08	< 13.00	No	No	
ASBESTOS-ST10-5/13/08	030814784-0005	North Side Sidewalk Bridge	5/13/08	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/14/08	< 13.00	No	No	
ASBESTOS-ST11-5/13/08	030814784-0006	90 Trinity Place (roof level)	5/13/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/14/08	< 13.00	No	No	
ASBESTOS-ST12-5/13/08	030814784-0007	110 Greenwich Street (roof level)	5/13/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/14/08	< 13.00	No	No	
ASBESTOS-ST13-5/13/08	030814784-0008	Marriott Hotel, 38th Floor (roof level)	5/13/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/14/08	< 13.00	No	No	
ASBESTOS-ST14-5/13/08	030814784-0009	West Face - South end at corner (scaffolding level)	5/13/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/14/08	< 13.00	No	No	
ASBESTOS-ST15-5/13/08	030814784-0010	South Face - East end at corner (scaffolding level)	5/13/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/14/08	< 13.00	No	No	
ASBESTOS-ST16-5/13/08	030814784-0011	East Face - North end at corner (scaffolding level)	5/13/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/14/08	< 13.00	No	No	
ASBESTOS-ST17-5/13/08	030814784-0012	North Face - West end at corner (scaffolding level)	5/13/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/14/08	< 13.00	No	No	
ASBESTOS-ST1-5/14/08	030814846-0001	Southwest Area (sidewalk bridge level)	5/14/08	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/15/08	< 15.00	No	No	
ASBESTOS-ST2-5/14/08	030814846-0002	Southeast Area (sidewalk bridge level)	5/14/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/15/08	< 13.00	No	No	
ASBESTOS-ST4-5/14/08	030814846-0003	Northwest Area (street-level)	5/14/08	1	3.230	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/15/08	< 15.00	No	No	
ASBESTOS-ST5-5/14/08	030814846-0004	Firehouse #10 (roof level)	5/14/08	1	3.170	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/15/08	< 15.00	No	No	
ASBESTOS-ST10-5/14/08	030814846-0005	North Side Sidewalk Bridge	5/14/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/15/08	< 13.00	No	No	
ASBESTOS-ST11-5/14/08	030814846-0006	90 Trinity Place (roof level)	5/14/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/15/08	< 13.00	No	No	
ASBESTOS-ST12-5/14/08	030814846-0007	110 Greenwich Street (roof level)	5/14/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/15/08	< 13.00	No	No	
ASBESTOS-ST13-5/14/08	030814846-0008	Marriott Hotel, 38th Floor (roof level)	5/14/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/15/08	< 15.00	No	No	
ASBESTOS-ST14-5/14/08	030814846-0009	West Face - South end at corner (scaffolding level)	5/14/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/15/08	< 13.00	No	No	
ASBESTOS-ST15-5/14/08	030814846-0010	South Face - East end at corner (scaffolding level)	5/14/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/15/08	< 13.00	No	No	
ASBESTOS-ST16-5/14/08	030814846-0011	East Face - North end at corner (scaffolding level)	5/14/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/15/08	< 13.00	No	No	
ASBESTOS-ST17-5/14/08	030814846-0012	North Face - West end at corner (scaffolding level)	5/14/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/15/08	< 13.00	No	No	