

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-5/24/08	030816138-0001	Southwest Area (sidewalk bridge level)	5/24/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST2-5/24/08	030816138-0002	Southeast Area (sidewalk bridge level)	5/24/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST4-5/24/08	030816138-0003	Northwest Area (street-level)	5/24/08	1	3.180	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST5-5/24/08	030816138-0004	Firehouse #10 (roof level)	5/24/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST10-5/24/08	030816138-0005	North Side Sidewalk Bridge	5/24/08	1	3.210	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST11-5/24/08	030816138-0006	90 Trinity Place (roof level)	5/24/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST12-5/24/08	030816138-0007	110 Greenwich Street (roof level)	5/24/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST13-5/24/08	030816138-0008	Marriott Hotel, 38th Floor (roof level)	5/24/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST14-5/24/08	030816138-0009	West Face - South end at corner (scaffolding level)	5/24/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST15-5/24/08	030816138-0010	South Face - East end at corner (scaffolding level)	5/24/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST16-5/24/08	030816138-0011	East Face - North end at corner (scaffolding level)	5/24/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST17-5/24/08	030816138-0012	North Face - West end at corner (scaffolding level)	5/24/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST1-5/25/08	030816143-0001	Southwest Area (sidewalk bridge level)	5/25/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST2-5/25/08	030816143-0002	Southeast Area (sidewalk bridge level)	5/25/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST4-5/25/08	030816143-0003	Northwest Area (street-level)	5/25/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST5-5/25/08	030816143-0004	Firehouse #10 (roof level)	5/25/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST10-5/25/08	030816143-0005	North Side Sidewalk Bridge	5/25/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST11-5/25/08	030816143-0006	90 Trinity Place (roof level)	5/25/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST12-5/25/08	030816143-0007	110 Greenwich Street (roof level)	5/25/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST13-5/25/08	030816143-0008	Marriott Hotel, 38th Floor (roof level)	5/25/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST14-5/25/08	030816143-0009	West Face - South end at corner (scaffolding level)	5/25/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST15-5/25/08	030816143-0010	South Face - East end at corner (scaffolding level)	5/25/08	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST16-5/25/08	030816143-0011	East Face - North end at corner (scaffolding level)	5/25/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST17-5/25/08	030816143-0012	North Face - West end at corner (scaffolding level)	5/25/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST1-5/26/08	030816144-0001	Southwest Area (sidewalk bridge level)	5/26/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST2-5/26/08	030816144-0002	Southeast Area (sidewalk bridge level)	5/26/08	1	3.210	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST4-5/26/08	030816144-0003	Northwest Area (street-level)	5/26/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST5-5/26/08	030816144-0004	Firehouse #10 (roof level)	5/26/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST10-5/26/08	030816144-0005	North Side Sidewalk Bridge	5/26/08	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST11-5/26/08	030816144-0006	90 Trinity Place (roof level)	5/26/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST12-5/26/08	030816144-0007	110 Greenwich Street (roof level)	5/26/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST13-5/26/08	030816144-0008	Marriott Hotel, 38th Floor (roof level)	5/26/08	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST14-5/26/08	030816144-0009	West Face - South end at corner (scaffolding level)	5/26/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST15-5/26/08	030816144-0010	South Face - East end at corner (scaffolding level)	5/26/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST16-5/26/08	030816144-0011	East Face - North end at corner (scaffolding level)	5/26/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	
ASBESTOS-ST17-5/26/08	030816144-0012	North Face - West end at corner (scaffolding level)	5/26/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/27/08	< 13.00	No	No	