

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
Target Air Quality Levels											NA		
EPA Site Specific Trigger Levels											70		
ASBESTOS-ST1-5/27/08	030816249-0001	Southwest Area (sidewalk bridge level)	5/27/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/28/08	< 13.00	No	No	
ASBESTOS-ST2-5/27/08	030816249-0002	Southeast Area (sidewalk bridge level)	5/27/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/28/08	< 13.00	No	No	
ASBESTOS-ST4-5/27/08	030816249-0003	Northwest Area (street-level)	5/27/08	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/28/08	< 13.00	No	No	
ASBESTOS-ST5-5/27/08	030816249-0004	Firehouse #10 (roof level)	5/27/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/28/08	< 13.00	No	No	
ASBESTOS-ST10-5/27/08	030816249-0005	North Side Sidewalk Bridge	5/27/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/28/08	< 13.00	No	No	
ASBESTOS-ST11-5/27/08	030816249-0006	90 Trinity Place (roof level)	5/27/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/28/08	< 13.00	No	No	
ASBESTOS-ST12-5/27/08	030816249-0007	110 Greenwich Street (roof level)	5/27/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/28/08	< 13.00	No	No	
ASBESTOS-ST13-5/27/08	030816249-0008	Marriott Hotel, 38th Floor (roof level)	5/27/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/28/08	< 13.00	No	No	
ASBESTOS-ST14-5/27/08	030816249-0009	West Face - South end at corner (scaffolding level)	5/27/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/28/08	< 13.00	No	No	
ASBESTOS-ST15-5/27/08	030816249-0010	South Face - East end at corner (scaffolding level)	5/27/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/28/08	< 13.00	No	No	
ASBESTOS-ST16-5/27/08	030816249-0011	East Face - North end at corner (scaffolding level)	5/27/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/28/08	< 13.00	No	No	
ASBESTOS-ST17-5/27/08	030816249-0012	North Face - West end at corner (scaffolding level)	5/27/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/28/08	< 13.00	No	No	
ASBESTOS-ST1-5/28/08	030816412-0001	Southwest Area (sidewalk bridge level)	5/28/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/29/08	< 13.00	No	No	
ASBESTOS-ST2-5/28/08	030816412-0002	Southeast Area (sidewalk bridge level)	5/28/08	1	2.840	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/29/08	< 13.00	No	No	
ASBESTOS-ST4-5/28/08	030816412-0003	Northwest Area (street-level)	5/28/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/29/08	< 13.00	No	No	
ASBESTOS-ST5-5/28/08	030816412-0004	Firehouse #10 (roof level)	5/28/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/29/08	< 13.00	No	No	
ASBESTOS-ST10-5/28/08	030816412-0005	North Side Sidewalk Bridge	5/28/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/29/08	< 13.00	No	No	
ASBESTOS-ST100-5/28/08	030816412-0013	Station 10 Field Duplicate	5/28/08	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/29/08	< 13.00	No	No	
ASBESTOS-ST11-5/28/08	030816412-0006	90 Trinity Place (roof level)	5/28/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/29/08	< 13.00	No	No	
ASBESTOS-ST12-5/28/08	030816412-0007	110 Greenwich Street (roof level)	5/28/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/29/08	< 13.00	No	No	
ASBESTOS-ST13-5/28/08	030816412-0008	Marriott Hotel, 38th Floor (roof level)	5/28/08	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/29/08	< 13.00	No	No	
ASBESTOS-ST14-5/28/08	030816412-0009	West Face - South end at corner (scaffolding level)	5/28/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/29/08	< 13.00	No	No	
ASBESTOS-ST15-5/28/08	030816412-0010	South Face - East end at corner (scaffolding level)	5/28/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/29/08	< 13.00	No	No	
ASBESTOS-ST16-5/28/08	030816412-0011	East Face - North end at corner (scaffolding level)	5/28/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/29/08	< 13.00	No	No	
ASBESTOS-ST17-5/28/08	030816412-0012	North Face - West end at corner (scaffolding level)	5/28/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/29/08	< 13.00	No	No	