

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
										NA	Air Quality	Exceeds EPA	
										70	Levels	Site Specific	
												Trigger Levels	
ASBESTOS-ST1-6/1/08	030816968-0001	Southwest Area (sidewalk bridge level)	6/1/08	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No	
ASBESTOS-ST2-6/1/08	030816968-0002	Southeast Area (sidewalk bridge level)	6/1/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No	
ASBESTOS-ST4-6/1/08	030816968-0003	Northwest Area (street-level)	6/1/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No	
ASBESTOS-ST5-6/1/08	030816968-0004	Firehouse #10 (roof level)	6/1/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No	
ASBESTOS-ST10-6/1/08	030816968-0005	North Side Sidewalk Bridge	6/1/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No	
ASBESTOS-ST11-6/1/08	030816968-0006	90 Trinity Place (roof level)	6/1/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No	
ASBESTOS-ST12-6/1/08	030816968-0007	110 Greenwich Street (roof level)	6/1/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No	
ASBESTOS-ST13-6/1/08	030816968-0008	Marriott Hotel, 38th Floor (roof level)	6/1/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No	
ASBESTOS-ST14-6/1/08	030816968-0009	West Face - South end at corner (scaffolding level)	6/1/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No	
ASBESTOS-ST15-6/1/08	030816968-0010	South Face - East end at corner (scaffolding level)	6/1/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No	
ASBESTOS-ST16-6/1/08	030816968-0011	East Face - North end at corner (scaffolding level)	6/1/08	1	2.920	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No	
ASBESTOS-ST17-6/1/08	030816968-0012	North Face - West end at corner (scaffolding level)	6/1/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No	
ASBESTOS-ST1-6/2/08	030817018-0001	Southwest Area (sidewalk bridge level)	6/2/08	1	2.900	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No	
ASBESTOS-ST2-6/2/08	030817018-0002	Southeast Area (sidewalk bridge level)	6/2/08	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No	
ASBESTOS-ST4-6/2/08	030817018-0003	Northwest Area (street-level)	6/2/08	1	3.160	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No	
ASBESTOS-ST5-6/2/08	030817018-0004	Firehouse #10 (roof level)	6/2/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No	
ASBESTOS-ST10-6/2/08	030817018-0005	North Side Sidewalk Bridge	6/2/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No	
ASBESTOS-ST11-6/2/08	030817018-0006	90 Trinity Place (roof level)	6/2/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No	
ASBESTOS-ST12-6/2/08	030817018-0007	110 Greenwich Street (roof level)	6/2/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No	
ASBESTOS-ST13-6/2/08	030817018-0008	Marriott Hotel, 38th Floor (roof level)	6/2/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No	
ASBESTOS-ST14-6/2/08	030817018-0009	West Face - South end at corner (scaffolding level)	6/2/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No	
ASBESTOS-ST15-6/2/08	030817018-0010	South Face - East end at corner (scaffolding level)	6/2/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No	
ASBESTOS-ST16-6/2/08	030817018-0011	East Face - North end at corner (scaffolding level)	6/2/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No	
ASBESTOS-ST17-6/2/08	030817018-0012	North Face - West end at corner (scaffolding level)	6/2/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No	