

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)		Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
										NA				
										70				
Target Air Quality Levels														
EPA Site Specific Trigger Levels														
ASBESTOS-ST1-6/5/08	030817480-0001	Southwest Area (sidewalk bridge level)	6/5/08	1	2.900	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/08	< 13.00		No	No	
ASBESTOS-ST2-6/5/08	030817480-0002	Southeast Area (sidewalk bridge level)	6/5/08	1	2.840	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/08	< 13.00		No	No	
ASBESTOS-ST4-6/5/08	030817480-0003	Northwest Area (street-level)	6/5/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/08	< 13.00		No	No	
ASBESTOS-ST5-6/5/08	030817480-0004	Firehouse #10 (roof level)	6/5/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/08	< 13.00		No	No	
ASBESTOS-ST10-6/5/08	030817480-0005	North Side Sidewalk Bridge	6/5/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/08	< 13.00		No	No	
ASBESTOS-ST100-6/5/08	030817480-0013	Station 10 Field Duplicate	6/5/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/08	< 13.00		No	No	
ASBESTOS-ST11-6/5/08	030817480-0006	90 Trinity Place (roof level)	6/5/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/08	< 13.00		No	No	
ASBESTOS-ST12-6/5/08	030817480-0007	110 Greenwich Street (roof level)	6/5/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/08	< 13.00		No	No	
ASBESTOS-ST13-6/5/08	030817480-0008	Marriott Hotel, 38th Floor (roof level)	6/5/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/08	< 13.00		No	No	
ASBESTOS-ST14-6/5/08	030817480-0009	West Face - South end at corner (scaffolding level)	6/5/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/08	< 13.00		No	No	
ASBESTOS-ST15-6/5/08	030817480-0010	South Face - East end at corner (scaffolding level)	6/5/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/08	< 13.00		No	No	
ASBESTOS-ST16-6/5/08	030817480-0011	East Face - North end at corner (scaffolding level)	6/5/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/08	< 13.00		No	No	
ASBESTOS-ST17-6/5/08	030817480-0012	North Face - West end at corner (scaffolding level)	6/5/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/08	< 13.00		No	No	
ASBESTOS-ST1-6/6/08	030817473-0001	Southwest Area (sidewalk bridge level)	6/6/08	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/08	< 13.00		No	No	
ASBESTOS-ST2-6/6/08	030817473-0002	Southeast Area (sidewalk bridge level)	6/6/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/08	< 13.00		No	No	
ASBESTOS-ST4-6/6/08	030817473-0003	Northwest Area (street-level)	6/6/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/08	< 13.00		No	No	
ASBESTOS-ST5-6/6/08	030817473-0004	Firehouse #10 (roof level)	6/6/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/08	< 13.00		No	No	
ASBESTOS-ST10-6/6/08	030817473-0005	North Side Sidewalk Bridge	6/6/08	1	3.160	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/08	< 13.00		No	No	
ASBESTOS-ST11-6/6/08	030817473-0006	90 Trinity Place (roof level)	6/6/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/08	< 13.00		No	No	
ASBESTOS-ST12-6/6/08	030817473-0007	110 Greenwich Street (roof level)	6/6/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/08	< 13.00		No	No	
ASBESTOS-ST13-6/6/08	030817473-0008	Marriott Hotel, 38th Floor (roof level)	6/6/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/08	< 13.00		No	No	
ASBESTOS-ST14-6/6/08	030817473-0009	West Face - South end at corner (scaffolding level)	6/6/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/08	< 13.00		No	No	
ASBESTOS-ST15-6/6/08	030817473-0010	South Face - East end at corner (scaffolding level)	6/6/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/08	< 13.00		No	No	
ASBESTOS-ST16-6/6/08	030817473-0011	East Face - North end at corner (scaffolding level)	6/6/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/08	< 13.00		No	No	
ASBESTOS-ST17-6/6/08	030817473-0012	North Face - West end at corner (scaffolding level)	6/6/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/08	< 13.00		No	No	
ASBESTOS-ST1-6/7/08	030817683-0001	Southwest Area (sidewalk bridge level)	6/7/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/9/08	< 13.00		No	No	
ASBESTOS-ST2-6/7/08	030817683-0002	Southeast Area (sidewalk bridge level)	6/7/08	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/9/08	< 13.00		No	No	
ASBESTOS-ST4-6/7/08	030817683-0003	Northwest Area (street-level)	6/7/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/9/08	< 13.00		No	No	
ASBESTOS-ST5-6/7/08	030817683-0004	Firehouse #10 (roof level)	6/7/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/9/08	< 13.00		No	No	
ASBESTOS-ST10-6/7/08	030817683-0005	North Side Sidewalk Bridge	6/7/08	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/9/08	< 13.00		No	No	
ASBESTOS-ST11-6/7/08	030817683-0006	90 Trinity Place (roof level)	6/7/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/9/08	< 13.00		No	No	
ASBESTOS-ST12-6/7/08	030817683-0007	110 Greenwich Street (roof level)	6/7/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/9/08	< 13.00		No	No	
ASBESTOS-ST13-6/7/08	030817683-0008	Marriott Hotel, 38th Floor (roof level)	6/7/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/9/08	< 13.00		No	No	
ASBESTOS-ST14-6/7/08	030817683-0009	West Face - South end at corner (scaffolding level)	6/7/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/9/08	< 13.00		No	No	
ASBESTOS-ST15-6/7/08	030817683-0010	South Face - East end at corner (scaffolding level)	6/7/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/9/08	< 13.00		No	No	
ASBESTOS-ST16-6/7/08	030817683-0011	East Face - North end at corner (scaffolding level)	6/7/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/9/08	< 13.00		No	No	
ASBESTOS-ST17-6/7/08	030817683-0012	North Face - West end at corner (scaffolding level)	6/7/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/9/08	< 13.00		No	No	
ASBESTOS-ST1-6/8/08	030817674-0001	Southwest Area (sidewalk bridge level)	6/8/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/9/08	< 13.00		No	No	
ASBESTOS-ST2-6/8/08	030817674-0002	Southeast Area (sidewalk bridge level)	6/8/08	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/9/08	< 13.00		No	No	
ASBESTOS-ST4-6/8/08	030817674-0003	Northwest Area (street-level)	6/8/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/9/08	< 13.00		No	No	
ASBESTOS-ST5-6/8/08	030817674-0004	Firehouse #10 (roof level)	6/8/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/9/08	< 13.00		No	No	
ASBESTOS-ST10-6/8/08	030817674-0005	North Side Sidewalk Bridge	6/8/08	1	3.160	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/9/08	< 13.00		No	No	
ASBESTOS-ST11-6/8/08	030817674-0006	90 Trinity Place (roof level)	6/8/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/9/08	< 13.00		No	No	
ASBESTOS-ST12-6/8/08	030817674-0007	110 Greenwich Street (roof level)	6/8/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/9/08	< 13.00		No	No	
ASBESTOS-ST13-6/8/08	030817674-0008	Marriott Hotel, 38th Floor (roof level)	6/8/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/9/08	< 13.00		No	No	
ASBESTOS-ST14-6/8/08	030817674-0009	West Face - South end at corner (scaffolding level)	6/8/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/9/08	< 13.00		No	No	
ASBESTOS-ST15-6/8/08	030817674-0010	South Face - East end at corner (scaffolding level)	6/8/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/9/08	< 13.00		No	No	
ASBESTOS-ST16-6/8/08	030817674-0011	East Face - North end at corner (scaffolding level)	6/8/08	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/9/08	< 13.00		No	No	
ASBESTOS-ST17-6/8/08	030817674-0012	North Face - West end at corner (scaffolding level)	6/8/08	1	2.820	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/9/08	< 13.00		No	No	