

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
										NA	Air Quality Levels	Site Specific Trigger Levels	
										70			
ASBESTOS-ST1-6/5/10	031014910-0001	Southwest Area (sidewalk bridge level)	6/5/10	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/10	< 13.00	No	No	
ASBESTOS-ST2-6/5/10	031014910-0002	Southeast Area (sidewalk bridge level)	6/5/10	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/10	< 13.00	No	No	
ASBESTOS-ST4-6/5/10	031014910-0003	Northwest Area (street-level)	6/5/10	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/10	< 13.00	No	No	
ASBESTOS-ST5-6/5/10	031014910-0004	Firehouse #10 (roof level)	6/5/10	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/10	< 15.00	No	No	
ASBESTOS-ST11-6/5/10	031014910-0006	90 Trinity Place (roof level)	6/5/10	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/10	< 13.00	No	No	
ASBESTOS-ST12-6/5/10	031014910-0007	110 Greenwich Street (roof level)	6/5/10	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/10	< 13.00	No	No	
ASBESTOS-ST20-6/5/10	031014910-0005	Northeast Area, Sidewalk Bridge	6/5/10	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/10	< 13.00	No	No	
ASBESTOS-ST21-6/5/10	031014910-0008	Marriott Hotel, 4th Floor	6/5/10	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/7/10	< 13.00	No	No	