

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-6/10/08	030817943-0001	Southwest Area (sidewalk bridge level)	6/10/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/08	< 13.00	No	No	
ASBESTOS-ST2-6/10/08	030817943-0002	Southeast Area (sidewalk bridge level)	6/10/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/08	< 13.00	No	No	
ASBESTOS-ST4-6/10/08	030817943-0003	Northwest Area (street-level)	6/10/08	1	2.870	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/08	< 13.00	No	No	
ASBESTOS-ST5-6/10/08	030817943-0004	Firehouse #10 (roof level)	6/10/08	1	2.860	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/08	< 13.00	No	No	
ASBESTOS-ST10-6/10/08	030817943-0005	North Side Sidewalk Bridge	6/10/08	1	3.210	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/08	< 13.00	No	No	
ASBESTOS-ST11-6/10/08	030817943-0006	90 Trinity Place (roof level)	6/10/08	1	2.900	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/08	< 13.00	No	No	
ASBESTOS-ST12-6/10/08	030817943-0007	110 Greenwich Street (roof level)	6/10/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/08	< 13.00	No	No	
ASBESTOS-ST13-6/10/08	030817943-0008	Marriott Hotel, 38th Floor (roof level)	6/10/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/08	< 13.00	No	No	
ASBESTOS-ST14-6/10/08	030817943-0009	West Face - South end at corner (scaffolding level)	6/10/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/08	< 13.00	No	No	
ASBESTOS-ST15-6/10/08	030817943-0010	South Face - East end at corner (scaffolding level)	6/10/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/08	< 13.00	No	No	
ASBESTOS-ST16-6/10/08	030817943-0011	East Face - North end at corner (scaffolding level)	6/10/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/08	< 13.00	No	No	
ASBESTOS-ST17-6/10/08	030817943-0012	North Face - West end at corner (scaffolding level)	6/10/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/08	< 13.00	No	No	
ASBESTOS-ST1-6/11/08	030818159-0001	Southwest Area (sidewalk bridge level)	6/11/08	1	2.760	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/12/08	< 13.00	No	No	
ASBESTOS-ST2-6/11/08	030818159-0002	Southeast Area (sidewalk bridge level)	6/11/08	1	2.920	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/12/08	< 13.00	No	No	
ASBESTOS-ST4-6/11/08	030818159-0003	Northwest Area (street-level)	6/11/08	1	3.160	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/12/08	< 13.00	No	No	
ASBESTOS-ST5-6/11/08	030818159-0004	Firehouse #10 (roof level)	6/11/08	1	3.210	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/12/08	< 13.00	No	No	
ASBESTOS-ST10-6/11/08	030818159-0005	North Side Sidewalk Bridge	6/11/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/12/08	< 13.00	No	No	
ASBESTOS-ST11-6/11/08	030818159-0006	90 Trinity Place (roof level)	6/11/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/12/08	< 13.00	No	No	
ASBESTOS-ST12-6/11/08	030818159-0007	110 Greenwich Street (roof level)	6/11/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/12/08	< 13.00	No	No	
ASBESTOS-ST13-6/11/08	030818159-0008	Marriott Hotel, 38th Floor (roof level)	6/11/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/12/08	< 13.00	No	No	
ASBESTOS-ST14-6/11/08	030818159-0009	West Face - South end at corner (scaffolding level)	6/11/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/12/08	< 13.00	No	No	
ASBESTOS-ST15-6/11/08	030818159-0010	South Face - East end at corner (scaffolding level)	6/11/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/12/08	< 13.00	No	No	
ASBESTOS-ST16-6/11/08	030818159-0011	East Face - North end at corner (scaffolding level)	6/11/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/12/08	< 13.00	No	No	
ASBESTOS-ST17-6/11/08	030818159-0012	North Face - West end at corner (scaffolding level)	6/11/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/12/08	< 13.00	No	No	