

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments	
										NA	Air Quality Levels	Site Specific Trigger Levels		
										70				
Target Air Quality Levels														
EPA Site Specific Trigger Levels														
ASBESTOS-ST1-6/15/06	030618393-0001	Southwest Area (sidewalk bridge level)	6/15/06	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/16/06	< 13.00	No	No		
ASBESTOS-ST2-6/15/06	030618393-0002	Southeast Area (sidewalk bridge level)	6/15/06	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/16/06	< 13.00	No	No		
ASBESTOS-ST4-6/15/06	030618393-0003	Northwest Area (street-level)	6/15/06	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/16/06	< 13.00	No	No		
ASBESTOS-ST5-6/15/06	030618393-0004	Firehouse #10 (roof level)	6/15/06	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/16/06	< 13.00	No	No		
ASBESTOS-ST10-6/15/06	030618393-0005	North Side Sidewalk Bridge	6/15/06	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/16/06	< 13.00	No	No		
ASBESTOS-ST11-6/15/06	030618393-0006	90 Trinity Place (roof level)	6/15/06	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/16/06	< 13.00	No	No		
ASBESTOS-ST12-6/15/06	030618393-0007	110 Greenwich Street (roof level)	6/15/06	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/16/06	< 13.00	No	No		
ASBESTOS-ST13-6/15/06	030618393-0008	Marriott Hotel, 38th Floor (roof level)	6/15/06	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/16/06	< 13.00	No	No		
ASBESTOS-ST14-6/15/06	030618393-0009	West Face - South end at corner (scaffolding level)	6/15/06	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/16/06	< 13.00	No	No		
ASBESTOS-ST15-6/15/06	030618393-0010	South Face - East end at corner (scaffolding level)	6/15/06	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/16/06	< 13.00	No	No		
ASBESTOS-ST16-6/15/06	030618393-0011	East Face - North end at corner (scaffolding level)	6/15/06	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/16/06	< 13.00	No	No		
ASBESTOS-ST17-6/15/06	030618393-0012	North Face - West end at corner (scaffolding level)	6/15/06	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/16/06	< 13.00	No	No		