

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)		Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
										NA				
										70				
Target Air Quality Levels														
EPA Site Specific Trigger Levels														
ASBESTOS-ST1-6/17/08	030819007-0001	Southwest Area (sidewalk bridge level)	6/17/08	1	2.900	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/18/08	< 13.00	No	No		
ASBESTOS-ST2-6/17/08	030819007-0002	Southeast Area (sidewalk bridge level)	6/17/08	1	2.920	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/18/08	< 13.00	No	No		
ASBESTOS-ST4-6/17/08	030819007-0003	Northwest Area (street-level)	6/17/08	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/18/08	< 13.00	No	No		
ASBESTOS-ST5-6/17/08	030819007-0004	Firehouse #10 (roof level)	6/17/08	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/18/08	< 13.00	No	No		
ASBESTOS-ST10-6/17/08	030819007-0005	North Side Sidewalk Bridge	6/17/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/18/08	< 13.00	No	No		
ASBESTOS-ST11-6/17/08	030819007-0006	90 Trinity Place (roof level)	6/17/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/18/08	< 13.00	No	No		
ASBESTOS-ST12-6/17/08	030819007-0007	110 Greenwich Street (roof level)	6/17/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/18/08	< 13.00	No	No		
ASBESTOS-ST13-6/17/08	030819007-0008	Marriott Hotel, 38th Floor (roof level)	6/17/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/18/08	< 13.00	No	No		
ASBESTOS-ST14-6/17/08	030819007-0009	West Face - South end at corner (scaffolding level)	6/17/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/18/08	< 13.00	No	No		
ASBESTOS-ST15-6/17/08	030819007-0010	South Face - East end at corner (scaffolding level)	6/17/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/18/08	< 13.00	No	No		
ASBESTOS-ST16-6/17/08	030819007-0011	East Face - North end at corner (scaffolding level)	6/17/08	1	2.900	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/18/08	< 13.00	No	No		
ASBESTOS-ST17-6/17/08	030819007-0012	North Face - West end at corner (scaffolding level)	6/17/08	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/18/08	< 13.00	No	No		
ASBESTOS-ST1-6/18/08	030819162-0001	Southwest Area (sidewalk bridge level)	6/18/08	1	3.280	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/19/08	< 13.00	No	No		
ASBESTOS-ST2-6/18/08	030819162-0002	Southeast Area (sidewalk bridge level)	6/18/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/19/08	< 13.00	No	No		
ASBESTOS-ST4-6/18/08	030819162-0003	Northwest Area (street-level)	6/18/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/19/08	< 13.00	No	No		
ASBESTOS-ST5-6/18/08	030819162-0004	Firehouse #10 (roof level)	6/18/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/19/08	< 13.00	No	No		
ASBESTOS-ST10-6/18/08	030819162-0005	North Side Sidewalk Bridge	6/18/08	1	3.170	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/19/08	< 13.00	No	No		
ASBESTOS-ST11-6/18/08	030819162-0006	90 Trinity Place (roof level)	6/18/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/19/08	< 13.00	No	No		
ASBESTOS-ST12-6/18/08	030819162-0007	110 Greenwich Street (roof level)	6/18/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/19/08	< 13.00	No	No		
ASBESTOS-ST13-6/18/08	030819162-0008	Marriott Hotel, 38th Floor (roof level)	6/18/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/19/08	< 13.00	No	No		
ASBESTOS-ST14-6/18/08	030819162-0009	West Face - South end at corner (scaffolding level)	6/18/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/19/08	< 13.00	No	No		
ASBESTOS-ST15-6/18/08	030819162-0010	South Face - East end at corner (scaffolding level)	6/18/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/19/08	< 13.00	No	No		
ASBESTOS-ST16-6/18/08	030819162-0011	East Face - North end at corner (scaffolding level)	6/18/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/19/08	< 13.00	No	No		
ASBESTOS-ST17-6/18/08	030819162-0012	North Face - West end at corner (scaffolding level)	6/18/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/19/08	< 13.00	No	No		
ASBESTOS-ST1-6/19/08	030819369-0001	Southwest Area (sidewalk bridge level)	6/19/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/20/08	< 13.00	No	No		
ASBESTOS-ST2-6/19/08	030819369-0002	Southeast Area (sidewalk bridge level)	6/19/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/20/08	< 13.00	No	No		
ASBESTOS-ST4-6/19/08	030819369-0003	Northwest Area (street-level)	6/19/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/20/08	< 13.00	No	No		
ASBESTOS-ST5-6/19/08	030819369-0004	Firehouse #10 (roof level)	6/19/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/20/08	< 13.00	No	No		
ASBESTOS-ST10-6/19/08	030819369-0005	North Side Sidewalk Bridge	6/19/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/20/08	< 13.00	No	No		
ASBESTOS-ST11-6/19/08	030819369-0006	90 Trinity Place (roof level)	6/19/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/20/08	< 13.00	No	No		
ASBESTOS-ST12-6/19/08	030819369-0007	110 Greenwich Street (roof level)	6/19/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/20/08	< 13.00	No	No		
ASBESTOS-ST13-6/19/08	030819369-0008	Marriott Hotel, 38th Floor (roof level)	6/19/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/20/08	< 13.00	No	No		
ASBESTOS-ST14-6/19/08	030819369-0009	West Face - South end at corner (scaffolding level)	6/19/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/20/08	< 13.00	No	No		
ASBESTOS-ST15-6/19/08	030819369-0010	South Face - East end at corner (scaffolding level)	6/19/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/20/08	< 13.00	No	No		
ASBESTOS-ST16-6/19/08	030819369-0011	East Face - North end at corner (scaffolding level)	6/19/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/20/08	< 13.00	No	No		
ASBESTOS-ST17-6/19/08	030819369-0012	North Face - West end at corner (scaffolding level)	6/19/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/20/08	< 13.00	No	No		
ASBESTOS-ST1-6/20/08	030819481-0001	Southwest Area (sidewalk bridge level)	6/20/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/21/08	< 13.00	No	No		
ASBESTOS-ST2-6/20/08	030819481-0002	Southeast Area (sidewalk bridge level)	6/20/08	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/21/08	< 13.00	No	No		
ASBESTOS-ST4-6/20/08	030819481-0003	Northwest Area (street-level)	6/20/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/21/08	< 13.00	No	No		
ASBESTOS-ST5-6/20/08	030819481-0004	Firehouse #10 (roof level)	6/20/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/21/08	< 13.00	No	No		
ASBESTOS-ST10-6/20/08	030819481-0005	North Side Sidewalk Bridge	6/20/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/21/08	< 13.00	No	No		
ASBESTOS-ST11-6/20/08	030819481-0006	90 Trinity Place (roof level)	6/20/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/21/08	< 13.00	No	No		
ASBESTOS-ST12-6/20/08	030819481-0007	110 Greenwich Street (roof level)	6/20/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/21/08	< 13.00	No	No		
ASBESTOS-ST13-6/20/08	030819481-0008	Marriott Hotel, 38th Floor (roof level)	6/20/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/21/08	< 13.00	No	No		
ASBESTOS-ST14-6/20/08	030819481-0009	West Face - South end at corner (scaffolding level)	6/20/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/21/08	< 13.00	No	No		
ASBESTOS-ST15-6/20/08	030819481-0010	South Face - East end at corner (scaffolding level)	6/20/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/21/08	< 13.00	No	No		
ASBESTOS-ST16-6/20/08	030819481-0011	East Face - North end at corner (scaffolding level)	6/20/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/21/08	< 13.00	No	No		
ASBESTOS-ST17-6/20/08	030819481-0012	North Face - West end at corner (scaffolding level)	6/20/08	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/21/08	< 13.00	No	No		