

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)		Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
										NA	70			
										Target Air Quality Levels				
EPA Site Specific Trigger Levels										NA	70			
ASBESTOS-ST1-6/18/07	030719873-0001	Southwest Area (sidewalk bridge level)	6/18/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/19/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST2-6/18/07	030719873-0002	Southeast Area (sidewalk bridge level)	6/18/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/19/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST4-6/18/07	030719873-0003	Northwest Area (street-level)	6/18/07	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/19/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST5-6/18/07	030719873-0004	Firehouse #10 (roof level)	6/18/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/19/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST10-6/18/07	030719873-0005	North Side Sidewalk Bridge	6/18/07	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/19/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST100-6/18/07	030719873-0013	Station 10 Field Duplicate	6/18/07	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/19/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST11-6/18/07	030719873-0006	90 Trinity Place (roof level)	6/18/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/19/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST12-6/18/07	030719873-0007	110 Greenwich Street (roof level)	6/18/07	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/19/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST13-6/18/07	030719873-0008	Marriott Hotel, 38th Floor (roof level)	6/18/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/19/07	< 15.00	< 15.00	No	No	
ASBESTOS-ST14-6/18/07	030719873-0009	West Face - South end at corner (scaffolding level)	6/18/07	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/19/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST15-6/18/07	030719873-0010	South Face - East end at corner (scaffolding level)	6/18/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/19/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST16-6/18/07	030719873-0011	East Face - North end at corner (scaffolding level)	6/18/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/19/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST17-6/18/07	030719873-0012	North Face - West end at corner (scaffolding level)	6/18/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/19/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST1-6/19/07	030720010-0001	Southwest Area (sidewalk bridge level)	6/19/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/20/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST2-6/19/07	030720010-0002	Southeast Area (sidewalk bridge level)	6/19/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/20/07	< 15.00	< 15.00	No	No	
ASBESTOS-ST4-6/19/07	030720010-0003	Northwest Area (street-level)	6/19/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/20/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST5-6/19/07	030720010-0004	Firehouse #10 (roof level)	6/19/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/20/07	< 15.00	< 15.00	No	No	
ASBESTOS-ST10-6/19/07	030720010-0005	North Side Sidewalk Bridge	6/19/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/20/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST11-6/19/07	030720010-0006	90 Trinity Place (roof level)	6/19/07	1	3.190	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/20/07	< 15.00	< 15.00	No	No	
ASBESTOS-ST12-6/19/07	030720010-0007	110 Greenwich Street (roof level)	6/19/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/20/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST13-6/19/07	030720010-0008	Marriott Hotel, 38th Floor (roof level)	6/19/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/20/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST14-6/19/07	030720010-0009	West Face - South end at corner (scaffolding level)	6/19/07	1	3.230	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/20/07	< 15.00	< 15.00	No	No	
ASBESTOS-ST15-6/19/07	030720010-0010	South Face - East end at corner (scaffolding level)	6/19/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/20/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST16-6/19/07	030720010-0011	East Face - North end at corner (scaffolding level)	6/19/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/20/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST17-6/19/07	030720010-0012	North Face - West end at corner (scaffolding level)	6/19/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/20/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST1-6/20/07	030720210-0001	Southwest Area (sidewalk bridge level)	6/20/07	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/21/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST2-6/20/07	030720210-0002	Southeast Area (sidewalk bridge level)	6/20/07	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/21/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST4-6/20/07	030720210-0003	Northwest Area (street-level)	6/20/07	1	2.900	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/21/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST5-6/20/07	030720210-0004	Firehouse #10 (roof level)	6/20/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/21/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST10-6/20/07	030720210-0005	North Side Sidewalk Bridge	6/20/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/21/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST11-6/20/07	030720210-0006	90 Trinity Place (roof level)	6/20/07	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/21/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST12-6/20/07	030720210-0007	110 Greenwich Street (roof level)	6/20/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/21/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST13-6/20/07	030720210-0008	Marriott Hotel, 38th Floor (roof level)	6/20/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/21/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST14-6/20/07	030720210-0009	West Face - South end at corner (scaffolding level)	6/20/07	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/21/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST15-6/20/07	030720210-0010	South Face - East end at corner (scaffolding level)	6/20/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/21/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST16-6/20/07	030720210-0011	East Face - North end at corner (scaffolding level)	6/20/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/21/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST17-6/20/07	030720210-0012	North Face - West end at corner (scaffolding level)	6/20/07	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/21/07	< 13.00	< 13.00	No	No	