

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
										NA	Air Quality Levels	Site Specific Trigger Levels	
										70			
										Target Air Quality Levels			
										EPA Site Specific Trigger Levels			
ASBESTOS-ST1-6/27/07	030721167-0001	Southwest Area (sidewalk bridge level)	6/27/07	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/28/07	< 13.00	No	No	
ASBESTOS-ST2-6/27/07	030721167-0002	Southeast Area (sidewalk bridge level)	6/27/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/28/07	< 13.00	No	No	
ASBESTOS-ST4-6/27/07	030721167-0003	Northwest Area (street-level)	6/27/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/28/07	< 13.00	No	No	
ASBESTOS-ST5-6/27/07	030721167-0004	Firehouse #10 (roof level)	6/27/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/28/07	< 13.00	No	No	
ASBESTOS-ST10-6/27/07	030721167-0005	North Side Sidewalk Bridge	6/27/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/28/07	< 13.00	No	No	
ASBESTOS-ST11-6/27/07	030721167-0006	90 Trinity Place (roof level)	6/27/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/28/07	< 13.00	No	No	
ASBESTOS-ST12-6/27/07	030721167-0007	110 Greenwich Street (roof level)	6/27/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/28/07	< 13.00	No	No	
ASBESTOS-ST13-6/27/07	030721167-0008	Marriott Hotel, 38th Floor (roof level)	6/27/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/28/07	< 13.00	No	No	
ASBESTOS-ST14-6/27/07	030721167-0009	West Face - South end at corner (scaffolding level)	6/27/07	1	3.230	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/28/07	< 13.00	No	No	
ASBESTOS-ST15-6/27/07	030721167-0010	South Face - East end at corner (scaffolding level)	6/27/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/28/07	< 13.00	No	No	
ASBESTOS-ST16-6/27/07	030721167-0011	East Face - North end at corner (scaffolding level)	6/27/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/28/07	< 13.00	No	No	
ASBESTOS-ST17-6/27/07	030721167-0012	North Face - West end at corner (scaffolding level)	6/27/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/28/07	< 13.00	No	No	
ASBESTOS-ST1-6/28/07	030721317-0001	Southwest Area (sidewalk bridge level)	6/28/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/29/07	< 13.00	No	No	
ASBESTOS-ST2-6/28/07	030721317-0002	Southeast Area (sidewalk bridge level)	6/28/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/29/07	< 13.00	No	No	
ASBESTOS-ST4-6/28/07	030721317-0003	Northwest Area (street-level)	6/28/07	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/29/07	< 13.00	No	No	
ASBESTOS-ST5-6/28/07	030721317-0004	Firehouse #10 (roof level)	6/28/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/29/07	< 13.00	No	No	
ASBESTOS-ST10-6/28/07	030721317-0005	North Side Sidewalk Bridge	6/28/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/29/07	< 13.00	No	No	
ASBESTOS-ST11-6/28/07	030721317-0006	90 Trinity Place (roof level)	6/28/07	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/29/07	< 13.00	No	No	
ASBESTOS-ST12-6/28/07	030721317-0007	110 Greenwich Street (roof level)	6/28/07	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/29/07	< 13.00	No	No	
ASBESTOS-ST13-6/28/07	030721317-0008	Marriott Hotel, 38th Floor (roof level)	6/28/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/29/07	< 13.00	No	No	
ASBESTOS-ST14-6/28/07	030721317-0009	West Face - South end at corner (scaffolding level)	6/28/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/29/07	< 13.00	No	No	
ASBESTOS-ST15-6/28/07	030721317-0010	South Face - East end at corner (scaffolding level)	6/28/07	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/29/07	< 13.00	No	No	
ASBESTOS-ST16-6/28/07	030721317-0011	East Face - North end at corner (scaffolding level)	6/28/07	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/29/07	< 13.00	No	No	
ASBESTOS-ST17-6/28/07	030721317-0012	North Face - West end at corner (scaffolding level)	6/28/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/29/07	< 13.00	No	No	