

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
										NA	Air Quality	Exceeds EPA	
										70	Levels	Site Specific	
												Trigger Levels	
ASBESTOS-ST1-7/7/08	030821893-0001	Southwest Area (sidewalk bridge level)	7/7/08	1	3.280	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/8/08	< 13.00	No	No	
ASBESTOS-ST2-7/7/08	030821893-0002	Southeast Area (sidewalk bridge level)	7/7/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/8/08	< 13.00	No	No	
ASBESTOS-ST4-7/7/08	030821893-0003	Northwest Area (street-level)	7/7/08	1	3.260	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/8/08	< 13.00	No	No	
ASBESTOS-ST5-7/7/08	030821893-0004	Firehouse #10 (roof level)	7/7/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/8/08	< 13.00	No	No	
ASBESTOS-ST10-7/7/08	030821893-0005	North Side Sidewalk Bridge	7/7/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/8/08	< 13.00	No	No	
ASBESTOS-ST11-7/7/08	030821893-0006	90 Trinity Place (roof level)	7/7/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/8/08	< 13.00	No	No	
ASBESTOS-ST12-7/7/08	030821893-0007	110 Greenwich Street (roof level)	7/7/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/8/08	< 13.00	No	No	
ASBESTOS-ST13-7/7/08	030821893-0008	Marriott Hotel, 38th Floor (roof level)	7/7/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/8/08	< 13.00	No	No	
ASBESTOS-ST14-7/7/08	030821893-0009	West Face - South end at corner (scaffolding level)	7/7/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/8/08	< 13.00	No	No	
ASBESTOS-ST15-7/7/08	030821893-0010	South Face - East end at corner (scaffolding level)	7/7/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/8/08	< 13.00	No	No	
ASBESTOS-ST16-7/7/08	030821893-0011	East Face - North end at corner (scaffolding level)	7/7/08	1	3.340	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/8/08	< 13.00	No	No	
ASBESTOS-ST17-7/7/08	030821893-0012	North Face - West end at corner (scaffolding level)	7/7/08	1	2.900	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/8/08	< 13.00	No	No	
ASBESTOS-ST1-7/8/08	030822094-0001	Southwest Area (sidewalk bridge level)	7/8/08	1	3.310	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/9/08	< 13.00	No	No	
ASBESTOS-ST2-7/8/08	030822094-0002	Southeast Area (sidewalk bridge level)	7/8/08	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/9/08	< 13.00	No	No	
ASBESTOS-ST4-7/8/08	030822094-0003	Northwest Area (street-level)	7/8/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/9/08	< 13.00	No	No	
ASBESTOS-ST5-7/8/08	030822094-0004	Firehouse #10 (roof level)	7/8/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/9/08	< 13.00	No	No	
ASBESTOS-ST10-7/8/08	030822094-0005	North Side Sidewalk Bridge	7/8/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/9/08	< 13.00	No	No	
ASBESTOS-ST11-7/8/08	030822094-0006	90 Trinity Place (roof level)	7/8/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/9/08	< 13.00	No	No	
ASBESTOS-ST12-7/8/08	030822094-0007	110 Greenwich Street (roof level)	7/8/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/9/08	< 13.00	No	No	
ASBESTOS-ST13-7/8/08	030822094-0008	Marriott Hotel, 38th Floor (roof level)	7/8/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/9/08	< 13.00	No	No	
ASBESTOS-ST14-7/8/08	030822094-0009	West Face - South end at corner (scaffolding level)	7/8/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/9/08	< 13.00	No	No	
ASBESTOS-ST15-7/8/08	030822094-0010	South Face - East end at corner (scaffolding level)	7/8/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/9/08	< 13.00	No	No	
ASBESTOS-ST16-7/8/08	030822094-0011	East Face - North end at corner (scaffolding level)	7/8/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/9/08	< 13.00	No	No	
ASBESTOS-ST17-7/8/08	030822094-0012	North Face - West end at corner (scaffolding level)	7/8/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/9/08	< 13.00	No	No	