

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
Target Air Quality Levels										NA			
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-7/14/10	031019209-0001	Southwest Area (sidewalk bridge level)	7/14/10	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/15/10	< 13.00	No	No	
ASBESTOS-ST2-7/14/10	031019209-0002	Southeast Area (sidewalk bridge level)	7/14/10	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/15/10	< 13.00	No	No	
ASBESTOS-ST5-7/14/10	031019209-0003	Firehouse #10 (roof level)	7/14/10	1	3.130	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/15/10	< 13.00	No	No	
ASBESTOS-ST12-7/14/10	031019209-0006	110 Greenwich Street (roof level)	7/14/10	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/15/10	< 13.00	No	No	
ASBESTOS-ST20-7/14/10	031019209-0004	Northeast Area, Sidewalk Bridge	7/14/10	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/15/10	< 13.00	No	No	
ASBESTOS-ST200-7/14/10	031019209-0008	Station 20 Field Duplicate	7/14/10	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/15/10	< 13.00	No	No	
ASBESTOS-ST21-7/14/10	031019209-0007	Marriott Hotel, 4th Floor	7/14/10	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/15/10	< 13.00	No	No	
ASBESTOS-ST22-7/14/10	031019209-0005	Roof of 120 Cedar Street	7/14/10	1	3.160	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/15/10	< 13.00	No	No	
ASBESTOS-ST1-7/15/10	031019323-0001	Southwest Area (sidewalk bridge level)	7/15/10	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/16/10	< 13.00	No	No	
ASBESTOS-ST2-7/15/10	031019323-0002	Southeast Area (sidewalk bridge level)	7/15/10	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/16/10	< 15.00	No	No	
ASBESTOS-ST4-7/15/10	031019323-0003	Northwest Area (street-level)	7/15/10	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/16/10	< 15.00	No	No	
ASBESTOS-ST5-7/15/10	031019323-0004	Firehouse #10 (roof level)	7/15/10	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/16/10	< 15.00	No	No	
ASBESTOS-ST12-7/15/10	031019323-0007	110 Greenwich Street (roof level)	7/15/10	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/16/10	< 13.00	No	No	
ASBESTOS-ST20-7/15/10	031019323-0005	Northeast Area, Sidewalk Bridge	7/15/10	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/16/10	26.00	No	No	
ASBESTOS-ST21-7/15/10	031019323-0008	Marriott Hotel, 4th Floor	7/15/10	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/16/10	< 15.00	No	No	
ASBESTOS-ST22-7/15/10	031019323-0006	Roof of 120 Cedar Street	7/15/10	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/16/10	< 13.00	No	No	

Note:

1. The asbestos result from Station 4 (Northwest Area [street level]) on July 14, 2010 was not available for analysis on account of damage to the sample media.