

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)		Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
										Target Air Quality Levels				
										NA	70			
EPA Site Specific Trigger Levels														
ASBESTOS-ST1-7/17/08	030823724-0001	Southwest Area (sidewalk bridge level)	7/17/08	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/18/08	< 13.00		No	No	
ASBESTOS-ST2-7/17/08	030823724-0002	Southeast Area (sidewalk bridge level)	7/17/08	1	3.210	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/18/08	< 13.00		No	No	
ASBESTOS-ST4-7/17/08	030823724-0003	Northwest Area (street-level)	7/17/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/18/08	< 13.00		No	No	
ASBESTOS-ST5-7/17/08	030823724-0004	Firehouse #10 (roof level)	7/17/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/18/08	< 13.00		No	No	
ASBESTOS-ST10-7/17/08	030823724-0005	North Side Sidewalk Bridge	7/17/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/18/08	< 13.00		No	No	
ASBESTOS-ST100-7/17/08	030823724-0013	Station 10 Field Duplicate	7/17/08	1	2.920	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/18/08	< 13.00		No	No	
ASBESTOS-ST11-7/17/08	030823724-0006	90 Trinity Place (roof level)	7/17/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/18/08	< 13.00		No	No	
ASBESTOS-ST12-7/17/08	030823724-0007	110 Greenwich Street (roof level)	7/17/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/18/08	< 13.00		No	No	
ASBESTOS-ST13-7/17/08	030823724-0008	Marriott Hotel, 38th Floor (roof level)	7/17/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/18/08	< 13.00		No	No	
ASBESTOS-ST14-7/17/08	030823724-0009	West Face - South end at corner (scaffolding level)	7/17/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/18/08	< 13.00		No	No	
ASBESTOS-ST15-7/17/08	030823724-0010	South Face - East end at corner (scaffolding level)	7/17/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/18/08	< 13.00		No	No	
ASBESTOS-ST16-7/17/08	030823724-0011	East Face - North end at corner (scaffolding level)	7/17/08	1	2.510	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/18/08	< 11.00		No	No	
ASBESTOS-ST17-7/17/08	030823724-0012	North Face - West end at corner (scaffolding level)	7/17/08	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/18/08	< 13.00		No	No	
ASBESTOS-ST1-7/18/08	030823950-0001	Southwest Area (sidewalk bridge level)	7/18/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/19/08	< 13.00		No	No	
ASBESTOS-ST2-7/18/08	030823950-0002	Southeast Area (sidewalk bridge level)	7/18/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/19/08	< 13.00		No	No	
ASBESTOS-ST4-7/18/08	030823950-0003	Northwest Area (street-level)	7/18/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/19/08	< 13.00		No	No	
ASBESTOS-ST5-7/18/08	030823950-0004	Firehouse #10 (roof level)	7/18/08	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/19/08	< 13.00		No	No	
ASBESTOS-ST10-7/18/08	030823950-0005	North Side Sidewalk Bridge	7/18/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/19/08	< 13.00		No	No	
ASBESTOS-ST11-7/18/08	030823950-0006	90 Trinity Place (roof level)	7/18/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/19/08	< 13.00		No	No	
ASBESTOS-ST12-7/18/08	030823950-0007	110 Greenwich Street (roof level)	7/18/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/19/08	< 13.00		No	No	
ASBESTOS-ST13-7/18/08	030823950-0008	Marriott Hotel, 38th Floor (roof level)	7/18/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/19/08	< 13.00		No	No	
ASBESTOS-ST14-7/18/08	030823950-0009	West Face - South end at corner (scaffolding level)	7/18/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/19/08	< 13.00		No	No	
ASBESTOS-ST15-7/18/08	030823950-0010	South Face - East end at corner (scaffolding level)	7/18/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/19/08	< 13.00		No	No	
ASBESTOS-ST16-7/18/08	030823950-0011	East Face - North end at corner (scaffolding level)	7/18/08	1	3.190	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/19/08	< 13.00		No	No	
ASBESTOS-ST17-7/18/08	030823950-0012	North Face - West end at corner (scaffolding level)	7/18/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/19/08	< 13.00		No	No	
ASBESTOS-ST1-7/19/08	030824097-0001	Southwest Area (sidewalk bridge level)	7/19/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/21/08	< 13.00		No	No	
ASBESTOS-ST2-7/19/08	030824097-0002	Southeast Area (sidewalk bridge level)	7/19/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/21/08	< 13.00		No	No	
ASBESTOS-ST4-7/19/08	030824097-0003	Northwest Area (street-level)	7/19/08	1	3.290	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/21/08	< 13.00		No	No	
ASBESTOS-ST5-7/19/08	030824097-0004	Firehouse #10 (roof level)	7/19/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/21/08	< 13.00		No	No	
ASBESTOS-ST10-7/19/08	030824097-0005	North Side Sidewalk Bridge	7/19/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/21/08	< 13.00		No	No	
ASBESTOS-ST11-7/19/08	030824097-0006	90 Trinity Place (roof level)	7/19/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/21/08	< 13.00		No	No	
ASBESTOS-ST12-7/19/08	030824097-0007	110 Greenwich Street (roof level)	7/19/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/21/08	< 13.00		No	No	
ASBESTOS-ST13-7/19/08	030824097-0008	Marriott Hotel, 38th Floor (roof level)	7/19/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/21/08	< 13.00		No	No	
ASBESTOS-ST14-7/19/08	030824097-0009	West Face - South end at corner (scaffolding level)	7/19/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/21/08	< 13.00		No	No	
ASBESTOS-ST15-7/19/08	030824097-0010	South Face - East end at corner (scaffolding level)	7/19/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/21/08	< 13.00		No	No	
ASBESTOS-ST16-7/19/08	030824097-0011	East Face - North end at corner (scaffolding level)	7/19/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/21/08	< 13.00		No	No	
ASBESTOS-ST17-7/19/08	030824097-0012	North Face - West end at corner (scaffolding level)	7/19/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/21/08	< 13.00		No	No	
ASBESTOS-ST1-7/20/08	030824096-0001	Southwest Area (sidewalk bridge level)	7/20/08	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/21/08	< 13.00		No	No	
ASBESTOS-ST2-7/20/08	030824096-0002	Southeast Area (sidewalk bridge level)	7/20/08	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/21/08	< 13.00		No	No	
ASBESTOS-ST4-7/20/08	030824096-0003	Northwest Area (street-level)	7/20/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/21/08	< 13.00		No	No	
ASBESTOS-ST5-7/20/08	030824096-0004	Firehouse #10 (roof level)	7/20/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/21/08	< 13.00		No	No	
ASBESTOS-ST10-7/20/08	030824096-0005	North Side Sidewalk Bridge	7/20/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/21/08	< 13.00		No	No	
ASBESTOS-ST11-7/20/08	030824096-0006	90 Trinity Place (roof level)	7/20/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/21/08	< 13.00		No	No	
ASBESTOS-ST12-7/20/08	030824096-0007	110 Greenwich Street (roof level)	7/20/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/21/08	< 13.00		No	No	
ASBESTOS-ST13-7/20/08	030824096-0008	Marriott Hotel, 38th Floor (roof level)	7/20/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/21/08	< 13.00		No	No	
ASBESTOS-ST14-7/20/08	030824096-0009	West Face - South end at corner (scaffolding level)	7/20/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/21/08	< 13.00		No	No	
ASBESTOS-ST15-7/20/08	030824096-0010	South Face - East end at corner (scaffolding level)	7/20/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/21/08	< 13.00		No	No	
ASBESTOS-ST16-7/20/08	030824096-0011	East Face - North end at corner (scaffolding level)	7/20/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/21/08	< 13.00		No	No	
ASBESTOS-ST17-7/20/08	030824096-0012	North Face - West end at corner (scaffolding level)	7/20/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/21/08	< 13.00		No	No	