

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
										NA	Air Quality Levels	Site Specific Trigger Levels	
										70			
Target Air Quality Levels													
EPA Site Specific Trigger Levels													
ASBESTOS-ST1-7/22/08	030824470-0001	Southwest Area (sidewalk bridge level)	7/22/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/23/08	< 13.00	No	No	
ASBESTOS-ST2- 7/22/08	030824470-0002	Southeast Area (sidewalk bridge level)	7/22/08	1	3.160	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/23/08	< 13.00	No	No	
ASBESTOS-ST4- 7/22/08	030824470-0003	Northwest Area (street-level)	7/22/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/23/08	< 13.00	No	No	
ASBESTOS-ST5-7/22/08	030824470-0004	Firehouse #10 (roof level)	7/22/08	1	2.920	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/23/08	< 13.00	No	No	
ASBESTOS-ST10-7/22/08	030824470-0005	North Side Sidewalk Bridge	7/22/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/23/08	< 13.00	No	No	
ASBESTOS-ST11-7/22/08	030824470-0006	90 Trinity Place (roof level)	7/22/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/23/08	< 13.00	No	No	
ASBESTOS-ST12-7/22/08	030824470-0007	110 Greenwich Street (roof level)	7/22/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/23/08	< 13.00	No	No	
ASBESTOS-ST13-7/22/08	030824470-0008	Marriott Hotel, 38th Floor (roof level)	7/22/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/23/08	< 13.00	No	No	
ASBESTOS-ST14-7/22/08	030824470-0009	West Face - South end at corner (scaffolding level)	7/22/08	1	3.160	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/23/08	< 13.00	No	No	
ASBESTOS-ST15-7/22/08	030824470-0010	South Face - East end at corner (scaffolding level)	7/22/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/23/08	< 13.00	No	No	
ASBESTOS-ST16-7/22/08	030824470-0011	East Face - North end at corner (scaffolding level)	7/22/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/23/08	< 13.00	No	No	
ASBESTOS-ST17-7/22/08	030824470-0012	North Face - West end at corner (scaffolding level)	7/22/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/23/08	< 13.00	No	No	
ASBESTOS-ST1-7/23/08	030824695-0001	Southwest Area (sidewalk bridge level)	7/23/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/24/08	< 13.00	No	No	
ASBESTOS-ST2-7/23/08	030824695-0002	Southeast Area (sidewalk bridge level)	7/23/08	1	3.320	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/24/08	< 13.00	No	No	
ASBESTOS-ST4-7/23/08	030824695-0003	Northwest Area (street-level)	7/23/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/24/08	< 13.00	No	No	
ASBESTOS-ST10-7/23/08	030824695-0004	North Side Sidewalk Bridge	7/23/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/24/08	< 13.00	No	No	
ASBESTOS-ST11-7/23/08	030824695-0005	90 Trinity Place (roof level)	7/23/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/24/08	< 13.00	No	No	
ASBESTOS-ST12-7/23/08	030824695-0006	110 Greenwich Street (roof level)	7/23/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/24/08	< 13.00	No	No	
ASBESTOS-ST13-7/23/08	030824695-0007	Marriott Hotel, 38th Floor (roof level)	7/23/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/24/08	< 13.00	No	No	
ASBESTOS-ST14-7/23/08	030824695-0008	West Face - South end at corner (scaffolding level)	7/23/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/24/08	< 13.00	No	No	
ASBESTOS-ST15-7/23/08	030824695-0009	South Face - East end at corner (scaffolding level)	7/23/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/24/08	< 13.00	No	No	
ASBESTOS-ST16-7/23/08	030824695-0010	East Face - North end at corner (scaffolding level)	7/23/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/24/08	< 13.00	No	No	
ASBESTOS-ST17-7/23/08	030824695-0011	North Face - West end at corner (scaffolding level)	7/23/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/24/08	< 13.00	No	No	

Note:

- Asbestos sample at Station 5 (Firehouse #10 [roof level]) on July 23, 2008 was not available for analysis on account of pump failure.