

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-8/4/08	030826534-0001	Southwest Area (sidewalk bridge level)	8/4/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/5/08	< 13.00	No	No	
ASBESTOS-ST2-8/4/08	030826534-0002	Southeast Area (sidewalk bridge level)	8/4/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/5/08	< 13.00	No	No	
ASBESTOS-ST4-8/4/08	030826534-0003	Northwest Area (street-level)	8/4/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/5/08	< 13.00	No	No	
ASBESTOS-ST5-8/4/08	030826534-0004	Firehouse #10 (roof level)	8/4/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/5/08	< 13.00	No	No	
ASBESTOS-ST10-8/4/08	030826534-0005	North Side Sidewalk Bridge	8/4/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/5/08	< 13.00	No	No	
ASBESTOS-ST100-8/4/08	030826534-0012	Station 10 Field Duplicate	8/4/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/5/08	< 13.00	No	No	
ASBESTOS-ST11-8/4/08	030826534-0006	90 Trinity Place (roof level)	8/4/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/5/08	< 13.00	No	No	
ASBESTOS-ST12-8/4/08	030826534-0007	110 Greenwich Street (roof level)	8/4/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/5/08	< 13.00	No	No	
ASBESTOS-ST13-8/4/08	030826534-0008	Marriott Hotel, 38th Floor (roof level)	8/4/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/5/08	< 13.00	No	No	
ASBESTOS-ST14-8/4/08	030826534-0009	West Face - South end at corner (scaffolding level)	8/4/08	1	2.920	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/5/08	< 13.00	No	No	
ASBESTOS-ST15-8/4/08	030826534-0010	South Face - East end at corner (scaffolding level)	8/4/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/5/08	< 13.00	No	No	
ASBESTOS-ST16-8/4/08	030826534-0011	East Face - North end at corner (scaffolding level)	8/4/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/5/08	< 13.00	No	No	
ASBESTOS-ST17-8/4/08	030826534-0012	North Face - West end at corner (scaffolding level)	8/4/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/5/08	< 13.00	No	No	
ASBESTOS-ST1-8/5/08	030826707-0001	Southwest Area (sidewalk bridge level)	8/5/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/6/08	< 13.00	No	No	
ASBESTOS-ST2-8/5/08	030826707-0002	Southeast Area (sidewalk bridge level)	8/5/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/6/08	< 13.00	No	No	
ASBESTOS-ST4-8/5/08	030826707-0003	Northwest Area (street-level)	8/5/08	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/6/08	< 13.00	No	No	
ASBESTOS-ST5-8/5/08	030826707-0004	Firehouse #10 (roof level)	8/5/08	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/6/08	< 13.00	No	No	
ASBESTOS-ST10-8/5/08	030826707-0005	North Side Sidewalk Bridge	8/5/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/6/08	< 13.00	No	No	
ASBESTOS-ST11-8/5/08	030826707-0006	90 Trinity Place (roof level)	8/5/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/6/08	< 13.00	No	No	
ASBESTOS-ST12-8/5/08	030826707-0007	110 Greenwich Street (roof level)	8/5/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/6/08	< 13.00	No	No	
ASBESTOS-ST13-8/5/08	030826707-0008	Marriott Hotel, 38th Floor (roof level)	8/5/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/6/08	< 13.00	No	No	
ASBESTOS-ST14-8/5/08	030826707-0009	West Face - South end at corner (scaffolding level)	8/5/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/6/08	< 13.00	No	No	
ASBESTOS-ST15-8/5/08	030826707-0010	South Face - East end at corner (scaffolding level)	8/5/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/6/08	< 13.00	No	No	
ASBESTOS-ST16-8/5/08	030826707-0011	East Face - North end at corner (scaffolding level)	8/5/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/6/08	< 13.00	No	No	
ASBESTOS-ST17-8/5/08	030826707-0012	North Face - West end at corner (scaffolding level)	8/5/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/6/08	< 13.00	No	No	