

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
Target Air Quality Levels											NA		
EPA Site Specific Trigger Levels											70		
ASBESTOS-ST1-8/11/08	030827618-0001	Southwest Area (sidewalk bridge level)	8/11/08	1	3.190	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/12/08	< 13.00	No	No	
ASBESTOS-ST2-8/11/08	030827618-0002	Southeast Area (sidewalk bridge level)	8/11/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/12/08	< 13.00	No	No	
ASBESTOS-ST4-8/11/08	030827618-0003	Northwest Area (street-level)	8/11/08	1	3.220	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/12/08	< 13.00	No	No	
ASBESTOS-ST5-8/11/08	030827618-0004	Firehouse #10 (roof level)	8/11/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/12/08	< 13.00	No	No	
ASBESTOS-ST10-8/11/08	030827618-0005	North Side Sidewalk Bridge	8/11/08	1	3.190	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/12/08	< 13.00	No	No	
ASBESTOS-ST11-8/11/08	030827618-0006	90 Trinity Place (roof level)	8/11/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/12/08	< 13.00	No	No	
ASBESTOS-ST12-8/11/08	030827618-0007	110 Greenwich Street (roof level)	8/11/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/12/08	< 13.00	No	No	
ASBESTOS-ST13-8/11/08	030827618-0008	Marriott Hotel, 38th Floor (roof level)	8/11/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/12/08	< 13.00	No	No	
ASBESTOS-ST14-8/11/08	030827618-0009	West Face - South end at corner (scaffolding level)	8/11/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/12/08	< 13.00	No	No	
ASBESTOS-ST15-8/11/08	030827618-0010	South Face - East end at corner (scaffolding level)	8/11/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/12/08	< 13.00	No	No	
ASBESTOS-ST16-8/11/08	030827618-0011	East Face - North end at corner (scaffolding level)	8/11/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/12/08	< 13.00	No	No	
ASBESTOS-ST17-8/11/08	030827618-0012	North Face - West end at corner (scaffolding level)	8/11/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/12/08	< 13.00	No	No	
ASBESTOS-ST1-8/12/08	030827816-0001	Southwest Area (sidewalk bridge level)	8/12/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/13/08	< 15.00	No	No	
ASBESTOS-ST2-8/12/08	030827816-0002	Southeast Area (sidewalk bridge level)	8/12/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/13/08	< 15.00	No	No	
ASBESTOS-ST4-8/12/08	030827816-0003	Northwest Area (street-level)	8/12/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/13/08	< 15.00	No	No	
ASBESTOS-ST5-8/12/08	030827816-0004	Firehouse #10 (roof level)	8/12/08	1	3.160	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/13/08	< 15.00	No	No	
ASBESTOS-ST10-8/12/08	030827816-0005	North Side Sidewalk Bridge	8/12/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/13/08	< 13.00	No	No	
ASBESTOS-ST100-8/12/08	030827816-0013	Station 10 Field Duplicate	8/12/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/13/08	< 13.00	No	No	
ASBESTOS-ST11-8/12/08	030827816-0006	90 Trinity Place (roof level)	8/12/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/13/08	< 15.00	No	No	
ASBESTOS-ST12-8/12/08	030827816-0007	110 Greenwich Street (roof level)	8/12/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/13/08	< 13.00	No	No	
ASBESTOS-ST13-8/12/08	030827816-0008	Marriott Hotel, 38th Floor (roof level)	8/12/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/13/08	< 13.00	No	No	
ASBESTOS-ST14-8/12/08	030827816-0009	West Face - South end at corner (scaffolding level)	8/12/08	1	3.130	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/13/08	< 15.00	No	No	
ASBESTOS-ST15-8/12/08	030827816-0010	South Face - East end at corner (scaffolding level)	8/12/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/13/08	< 15.00	No	No	
ASBESTOS-ST16-8/12/08	030827816-0011	East Face - North end at corner (scaffolding level)	8/12/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/13/08	< 13.00	No	No	
ASBESTOS-ST17-8/12/08	030827816-0012	North Face - West end at corner (scaffolding level)	8/12/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/13/08	< 13.00	No	No	