

| TRC Field Sample No. | Sample No. | Sampling Location | Collection Start Date | Work Shift | Sample Volume (m ³) | Analyte | Analytical Method | Lab | Lab Sample Receipt Date | Asbestos AHERA Concentration (S/mm2) | Exceeds Target Air Quality Levels | Exceeds EPA Site Specific Trigger Levels | Comments |
|-----------------------|----------------|--|-----------------------|------------|---------------------------------|----------|---------------------------------|------|-------------------------|--------------------------------------|-----------------------------------|--|----------|
| | | | | | | | | | | NA | | | |
| | | | | | | | | | | 70 | | | |
| ASBESTOS-ST1-8/14/10 | 031022614-0001 | Southwest Area (sidewalk bridge level) | 8/14/10 | 1 | 3.070 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 8/16/10 | < 13.00 | No | No | |
| ASBESTOS-ST2-8/14/10 | 031022614-0002 | Southeast Area (sidewalk bridge level) | 8/14/10 | 1 | 3.020 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 8/16/10 | < 13.00 | No | No | |
| ASBESTOS-ST4-8/14/10 | 031022614-0003 | Northwest Area (street-level) | 8/14/10 | 1 | 3.000 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 8/16/10 | < 13.00 | No | No | |
| ASBESTOS-ST5-8/14/10 | 031022614-0004 | Firehouse #10 (roof level) | 8/14/10 | 1 | 3.030 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 8/16/10 | < 13.00 | No | No | |
| ASBESTOS-ST20-8/14/10 | 031022614-0005 | Northeast Area, Sidewalk Bridge | 8/14/10 | 1 | 3.070 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 8/16/10 | < 13.00 | No | No | |
| ASBESTOS-ST21-8/14/10 | 031022614-0006 | Marriott Hotel, 4th Floor | 8/14/10 | 1 | 3.120 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 8/16/10 | < 13.00 | No | No | |
| ASBESTOS-ST22-8/14/10 | 031022614-0007 | Roof of 120 Cedar Street | 8/14/10 | 1 | 3.100 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 8/16/10 | < 13.00 | No | No | |