

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-8/15/08	030828300-0001	Southwest Area (sidewalk bridge level)	8/15/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/16/08	< 13.00	No	No	
ASBESTOS-ST2-8/15/08	030828300-0002	Southeast Area (sidewalk bridge level)	8/15/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/16/08	< 15.00	No	No	
ASBESTOS-ST4-8/15/08	030828300-0003	Northwest Area (street-level)	8/15/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/16/08	< 15.00	No	No	
ASBESTOS-ST5-8/15/08	030828300-0004	Firehouse #10 (roof level)	8/15/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/16/08	< 13.00	No	No	
ASBESTOS-ST10-8/15/08	030828300-0005	North Side Sidewalk Bridge	8/15/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/16/08	< 13.00	No	No	
ASBESTOS-ST11-8/15/08	030828300-0006	90 Trinity Place (roof level)	8/15/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/16/08	< 13.00	No	No	
ASBESTOS-ST12-8/15/08	030828300-0007	110 Greenwich Street (roof level)	8/15/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/16/08	< 13.00	No	No	
ASBESTOS-ST13-8/15/08	030828300-0008	Marriott Hotel, 38th Floor (roof level)	8/15/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/16/08	< 13.00	No	No	
ASBESTOS-ST14-8/15/08	030828300-0009	West Face - South end at corner (scaffolding level)	8/15/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/16/08	< 13.00	No	No	
ASBESTOS-ST15-8/15/08	030828300-0010	South Face - East end at corner (scaffolding level)	8/15/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/16/08	< 13.00	No	No	
ASBESTOS-ST16-8/15/08	030828300-0011	East Face - North end at corner (scaffolding level)	8/15/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/16/08	< 13.00	No	No	
ASBESTOS-ST17-8/15/08	030828300-0012	North Face - West end at corner (scaffolding level)	8/15/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/16/08	< 13.00	No	No	
ASBESTOS-ST1-8/16/08	030828385-0001	Southwest Area (sidewalk bridge level)	8/16/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/08	< 15.00	No	No	
ASBESTOS-ST2-8/16/08	030828385-0002	Southeast Area (sidewalk bridge level)	8/16/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/08	< 13.00	No	No	
ASBESTOS-ST4-8/16/08	030828385-0003	Northwest Area (street-level)	8/16/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/08	< 15.00	No	No	
ASBESTOS-ST5-8/16/08	030828385-0004	Firehouse #10 (roof level)	8/16/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/08	< 15.00	No	No	
ASBESTOS-ST10-8/16/08	030828385-0005	North Side Sidewalk Bridge	8/16/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/08	< 15.00	No	No	
ASBESTOS-ST11-8/16/08	030828385-0006	90 Trinity Place (roof level)	8/16/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/08	< 13.00	No	No	
ASBESTOS-ST12-8/16/08	030828385-0007	110 Greenwich Street (roof level)	8/16/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/08	< 15.00	No	No	
ASBESTOS-ST13-8/16/08	030828385-0008	Marriott Hotel, 38th Floor (roof level)	8/16/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/08	< 15.00	No	No	
ASBESTOS-ST14-8/16/08	030828385-0009	West Face - South end at corner (scaffolding level)	8/16/08	1	3.170	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/08	< 15.00	No	No	
ASBESTOS-ST15-8/16/08	030828385-0010	South Face - East end at corner (scaffolding level)	8/16/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/08	< 15.00	No	No	
ASBESTOS-ST16-8/16/08	030828385-0011	East Face - North end at corner (scaffolding level)	8/16/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/08	< 15.00	No	No	
ASBESTOS-ST17-8/16/08	030828385-0012	North Face - West end at corner (scaffolding level)	8/16/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/08	< 15.00	No	No	
ASBESTOS-ST1-8/17/08	030828387-0001	Southwest Area (sidewalk bridge level)	8/17/08	1	3.160	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/08	< 15.00	No	No	
ASBESTOS-ST2-8/17/08	030828387-0002	Southeast Area (sidewalk bridge level)	8/17/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/08	< 15.00	No	No	
ASBESTOS-ST4-8/17/08	030828387-0003	Northwest Area (street-level)	8/17/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/08	< 15.00	No	No	
ASBESTOS-ST5-8/17/08	030828387-0004	Firehouse #10 (roof level)	8/17/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/08	< 15.00	No	No	
ASBESTOS-ST10-8/17/08	030828387-0005	North Side Sidewalk Bridge	8/17/08	1	2.920	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/08	< 13.00	No	No	
ASBESTOS-ST11-8/17/08	030828387-0006	90 Trinity Place (roof level)	8/17/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/08	< 15.00	No	No	
ASBESTOS-ST12-8/17/08	030828387-0007	110 Greenwich Street (roof level)	8/17/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/08	< 13.00	No	No	
ASBESTOS-ST13-8/17/08	030828387-0008	Marriott Hotel, 38th Floor (roof level)	8/17/08	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/08	< 13.00	No	No	
ASBESTOS-ST14-8/17/08	030828387-0009	West Face - South end at corner (scaffolding level)	8/17/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/08	< 15.00	No	No	
ASBESTOS-ST15-8/17/08	030828387-0010	South Face - East end at corner (scaffolding level)	8/17/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/08	< 13.00	No	No	
ASBESTOS-ST16-8/17/08	030828387-0011	East Face - North end at corner (scaffolding level)	8/17/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/08	< 13.00	No	No	
ASBESTOS-ST17-8/17/08	030828387-0012	North Face - West end at corner (scaffolding level)	8/17/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/08	< 15.00	No	No	