

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
Target Air Quality Levels										NA			
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-8/17/10	031022853-0001	Southwest Area (sidewalk bridge level)	8/17/10	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/10	< 13.00	No	No	
ASBESTOS-ST2-8/17/10	031022853-0002	Southeast Area (sidewalk bridge level)	8/17/10	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/10	< 13.00	No	No	
ASBESTOS-ST4-8/17/10	031022853-0003	Northwest Area (street-level)	8/17/10	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/10	< 13.00	No	No	
ASBESTOS-ST5-8/17/10	031022853-0004	Firehouse #10 (roof level)	8/17/10	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/10	< 13.00	No	No	
ASBESTOS-ST20-8/17/10	031022853-0005	Northeast Area, Sidewalk Bridge	8/17/10	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/10	< 13.00	No	No	
ASBESTOS-ST200-8/17/10	031022853-0008	Station 20 Field Duplicate	8/17/10	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/10	< 13.00	No	No	
ASBESTOS-ST21-8/17/10	031022853-0006	Marriott Hotel, 4th Floor	8/17/10	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/10	< 13.00	No	No	
ASBESTOS-ST22-8/17/10	031022853-0007	Roof of 120 Cedar Street	8/17/10	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/18/10	< 13.00	No	No	