

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)		Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
										NA	70			
										Target Air Quality Levels				
EPA Site Specific Trigger Levels														
ASBESTOS-ST1-8/19/08	030828787-0001	Southwest Area (sidewalk bridge level)	8/19/08	1	3.170	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/20/08	< 15.00		No	No	
ASBESTOS-ST2-8/19/08	030828787-0002	Southeast Area (sidewalk bridge level)	8/19/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/20/08	< 13.00		No	No	
ASBESTOS-ST4-8/19/08	030828787-0003	Northwest Area (street-level)	8/19/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/20/08	< 15.00		No	No	
ASBESTOS-ST5-8/19/08	030828787-0004	Firehouse #10 (roof level)	8/19/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/20/08	< 13.00		No	No	
ASBESTOS-ST10-8/19/08	030828787-0005	North Side Sidewalk Bridge	8/19/08	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/20/08	< 13.00		No	No	
ASBESTOS-ST11-8/19/08	030828787-0006	90 Trinity Place (roof level)	8/19/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/20/08	< 13.00		No	No	
ASBESTOS-ST12-8/19/08	030828787-0007	110 Greenwich Street (roof level)	8/19/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/20/08	< 13.00		No	No	
ASBESTOS-ST13-8/19/08	030828787-0008	Marriott Hotel, 38th Floor (roof level)	8/19/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/20/08	< 13.00		No	No	
ASBESTOS-ST14-8/19/08	030828787-0009	West Face - South end at corner (scaffolding level)	8/19/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/20/08	< 13.00		No	No	
ASBESTOS-ST15-8/19/08	030828787-0010	South Face - East end at corner (scaffolding level)	8/19/08	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/20/08	< 13.00		No	No	
ASBESTOS-ST16-8/19/08	030828787-0011	East Face - North end at corner (scaffolding level)	8/19/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/20/08	< 13.00		No	No	
ASBESTOS-ST17-8/19/08	030828787-0012	North Face - West end at corner (scaffolding level)	8/19/08	1	3.190	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/20/08	< 13.00		No	No	
ASBESTOS-ST1-8/20/08	030828975-0001	Southwest Area (sidewalk bridge level)	8/20/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/21/08	< 15.00		No	No	
ASBESTOS-ST2-8/20/08	030828975-0002	Southeast Area (sidewalk bridge level)	8/20/08	1	3.130	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/21/08	< 15.00		No	No	
ASBESTOS-ST4-8/20/08	030828975-0003	Northwest Area (street-level)	8/20/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/21/08	< 15.00		No	No	
ASBESTOS-ST5-8/20/08	030828975-0004	Firehouse #10 (roof level)	8/20/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/21/08	< 15.00		No	No	
ASBESTOS-ST10-8/20/08	030828975-0005	North Side Sidewalk Bridge	8/20/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/21/08	< 15.00		No	No	
ASBESTOS-ST100-8/20/08	030828975-0013	Station 10 Field Duplicate	8/20/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/21/08	< 15.00		No	No	
ASBESTOS-ST11-8/20/08	030828975-0006	90 Trinity Place (roof level)	8/20/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/21/08	< 13.00		No	No	
ASBESTOS-ST12-8/20/08	030828975-0007	110 Greenwich Street (roof level)	8/20/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/21/08	< 15.00		No	No	
ASBESTOS-ST13-8/20/08	030828975-0008	Marriott Hotel, 38th Floor (roof level)	8/20/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/21/08	< 13.00		No	No	
ASBESTOS-ST14-8/20/08	030828975-0009	West Face - South end at corner (scaffolding level)	8/20/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/21/08	< 15.00		No	No	
ASBESTOS-ST15-8/20/08	030828975-0010	South Face - East end at corner (scaffolding level)	8/20/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/21/08	< 15.00		No	No	
ASBESTOS-ST16-8/20/08	030828975-0011	East Face - North end at corner (scaffolding level)	8/20/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/21/08	< 13.00		No	No	
ASBESTOS-ST17-8/20/08	030828975-0012	North Face - West end at corner (scaffolding level)	8/20/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/21/08	< 15.00		No	No	
ASBESTOS-ST1-8/21/08	030829148-0001	Southwest Area (sidewalk bridge level)	8/21/08	1	3.180	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/22/08	< 15.00		No	No	
ASBESTOS-ST2-8/21/08	030829148-0002	Southeast Area (sidewalk bridge level)	8/21/08	1	3.160	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/22/08	< 15.00		No	No	
ASBESTOS-ST4-8/21/08	030829148-0003	Northwest Area (street-level)	8/21/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/22/08	< 15.00		No	No	
ASBESTOS-ST5-8/21/08	030829148-0004	Firehouse #10 (roof level)	8/21/08	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/22/08	< 13.00		No	No	
ASBESTOS-ST10-8/21/08	030829148-0005	North Side Sidewalk Bridge	8/21/08	1	2.860	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/22/08	< 13.00		No	No	
ASBESTOS-ST11-8/21/08	030829148-0006	90 Trinity Place (roof level)	8/21/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/22/08	< 13.00		No	No	
ASBESTOS-ST12-8/21/08	030829148-0007	110 Greenwich Street (roof level)	8/21/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/22/08	< 13.00		No	No	
ASBESTOS-ST13-8/21/08	030829148-0008	Marriott Hotel, 38th Floor (roof level)	8/21/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/22/08	< 13.00		No	No	
ASBESTOS-ST14-8/21/08	030829148-0009	West Face - South end at corner (scaffolding level)	8/21/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/22/08	< 13.00		No	No	
ASBESTOS-ST15-8/21/08	030829148-0010	South Face - East end at corner (scaffolding level)	8/21/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/22/08	< 13.00		No	No	
ASBESTOS-ST16-8/21/08	030829148-0011	East Face - North end at corner (scaffolding level)	8/21/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/22/08	< 13.00		No	No	
ASBESTOS-ST17-8/21/08	030829148-0012	North Face - West end at corner (scaffolding level)	8/21/08	1	3.250	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/22/08	< 13.00		No	No	
ASBESTOS-ST1-8/22/08	030829243-0001	Southwest Area (sidewalk bridge level)	8/22/08	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/23/08	< 13.00		No	No	
ASBESTOS-ST2-8/22/08	030829243-0002	Southeast Area (sidewalk bridge level)	8/22/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/23/08	< 13.00		No	No	
ASBESTOS-ST4-8/22/08	030829243-0003	Northwest Area (street-level)	8/22/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/23/08	< 13.00		No	No	
ASBESTOS-ST5-8/22/08	030829243-0004	Firehouse #10 (roof level)	8/22/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/23/08	< 13.00		No	No	
ASBESTOS-ST10-8/22/08	030829243-0005	North Side Sidewalk Bridge	8/22/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/23/08	< 13.00		No	No	
ASBESTOS-ST11-8/22/08	030829243-0006	90 Trinity Place (roof level)	8/22/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/23/08	< 13.00		No	No	
ASBESTOS-ST12-8/22/08	030829243-0007	110 Greenwich Street (roof level)	8/22/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/23/08	< 13.00		No	No	
ASBESTOS-ST13-8/22/08	030829243-0008	Marriott Hotel, 38th Floor (roof level)	8/22/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/23/08	< 13.00		No	No	
ASBESTOS-ST14-8/22/08	030829243-0009	West Face - South end at corner (scaffolding level)	8/22/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/23/08	< 13.00		No	No	
ASBESTOS-ST15-8/22/08	030829243-0010	South Face - East end at corner (scaffolding level)	8/22/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/23/08	< 13.00		No	No	
ASBESTOS-ST16-8/22/08	030829243-0011	East Face - North end at corner (scaffolding level)	8/22/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/23/08	< 13.00		No	No	
ASBESTOS-ST17-8/22/08	030829243-0012	North Face - West end at corner (scaffolding level)	8/22/08	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/23/08	< 13.00		No	No	