

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-8/23/08	030829385-0001	Southwest Area (sidewalk bridge level)	8/23/08	1	3.230	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/25/08	< 15.00	No	No	
ASBESTOS-ST2-8/23/08	030829385-0002	Southeast Area (sidewalk bridge level)	8/23/08	1	3.180	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/25/08	< 15.00	No	No	
ASBESTOS-ST4-8/23/08	030829385-0003	Northwest Area (street-level)	8/23/08	1	3.130	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/25/08	< 15.00	No	No	
ASBESTOS-ST5-8/23/08	030829385-0004	Firehouse #10 (roof level)	8/23/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/25/08	< 15.00	No	No	
ASBESTOS-ST10-8/23/08	030829385-0005	North Side Sidewalk Bridge	8/23/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/25/08	< 13.00	No	No	
ASBESTOS-ST11-8/23/08	030829385-0006	90 Trinity Place (roof level)	8/23/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/25/08	13.00	No	No	
ASBESTOS-ST12-8/23/08	030829385-0007	110 Greenwich Street (roof level)	8/23/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/25/08	< 13.00	No	No	
ASBESTOS-ST13-8/23/08	030829385-0008	Marriott Hotel, 38th Floor (roof level)	8/23/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/25/08	< 13.00	No	No	
ASBESTOS-ST14-8/23/08	030829385-0009	West Face - South end at corner (scaffolding level)	8/23/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/25/08	< 15.00	No	No	
ASBESTOS-ST15-8/23/08	030829385-0010	South Face - East end at corner (scaffolding level)	8/23/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/25/08	< 15.00	No	No	
ASBESTOS-ST16-8/23/08	030829385-0011	East Face - North end at corner (scaffolding level)	8/23/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/25/08	< 15.00	No	No	
ASBESTOS-ST17-8/23/08	030829385-0012	North Face - West end at corner (scaffolding level)	8/23/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/25/08	< 15.00	No	No	
ASBESTOS-ST1-8/24/08	030829491-0001	Southwest Area (sidewalk bridge level)	8/24/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/25/08	< 13.00	No	No	
ASBESTOS-ST2-8/24/08	030829491-0002	Southeast Area (sidewalk bridge level)	8/24/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/25/08	< 13.00	No	No	
ASBESTOS-ST4-8/24/08	030829491-0003	Northwest Area (street-level)	8/24/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/25/08	< 13.00	No	No	
ASBESTOS-ST5-8/24/08	030829491-0004	Firehouse #10 (roof level)	8/24/08	1	3.200	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/25/08	< 13.00	No	No	
ASBESTOS-ST10-8/24/08	030829491-0005	North Side Sidewalk Bridge	8/24/08	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/25/08	< 13.00	No	No	
ASBESTOS-ST11-8/24/08	030829491-0006	90 Trinity Place (roof level)	8/24/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/25/08	< 13.00	No	No	
ASBESTOS-ST12-8/24/08	030829491-0007	110 Greenwich Street (roof level)	8/24/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/25/08	< 13.00	No	No	
ASBESTOS-ST13-8/24/08	030829491-0008	Marriott Hotel, 38th Floor (roof level)	8/24/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/25/08	< 13.00	No	No	
ASBESTOS-ST14-8/24/08	030829491-0009	West Face - South end at corner (scaffolding level)	8/24/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/25/08	< 13.00	No	No	
ASBESTOS-ST15-8/24/08	030829491-0010	South Face - East end at corner (scaffolding level)	8/24/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/25/08	< 13.00	No	No	
ASBESTOS-ST16-8/24/08	030829491-0011	East Face - North end at corner (scaffolding level)	8/24/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/25/08	< 13.00	No	No	
ASBESTOS-ST17-8/24/08	030829491-0012	North Face - West end at corner (scaffolding level)	8/24/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/25/08	< 13.00	No	No	
ASBESTOS-ST1-8/25/08	030829612-0001	Southwest Area (sidewalk bridge level)	8/25/08	1	3.160	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/26/08	< 15.00	No	No	
ASBESTOS-ST2-8/25/08	030829612-0002	Southeast Area (sidewalk bridge level)	8/25/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/26/08	< 15.00	No	No	
ASBESTOS-ST4-8/25/08	030829612-0003	Northwest Area (street-level)	8/25/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/26/08	< 15.00	No	No	
ASBESTOS-ST5-8/25/08	030829612-0004	Firehouse #10 (roof level)	8/25/08	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/26/08	< 13.00	No	No	
ASBESTOS-ST10-8/25/08	030829612-0005	North Side Sidewalk Bridge	8/25/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/26/08	< 13.00	No	No	
ASBESTOS-ST11-8/25/08	030829612-0006	90 Trinity Place (roof level)	8/25/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/26/08	< 13.00	No	No	
ASBESTOS-ST12-8/25/08	030829612-0007	110 Greenwich Street (roof level)	8/25/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/26/08	< 13.00	No	No	
ASBESTOS-ST13-8/25/08	030829612-0008	Marriott Hotel, 38th Floor (roof level)	8/25/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/26/08	< 13.00	No	No	
ASBESTOS-ST14-8/25/08	030829612-0009	West Face - South end at corner (scaffolding level)	8/25/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/26/08	< 13.00	No	No	
ASBESTOS-ST15-8/25/08	030829612-0010	South Face - East end at corner (scaffolding level)	8/25/08	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/26/08	< 15.00	No	No	
ASBESTOS-ST16-8/25/08	030829612-0011	East Face - North end at corner (scaffolding level)	8/25/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/26/08	< 13.00	No	No	
ASBESTOS-ST17-8/25/08	030829612-0012	North Face - West end at corner (scaffolding level)	8/25/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/26/08	< 13.00	No	No	