

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality	Site Specific	Comments
EPA Site Specific Trigger Levels										70	Levels	Trigger Levels	
ASBESTOS-ST1-9/5/07	030730438-0001	Southwest Area (sidewalk bridge level)	9/5/07	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/6/07	< 13.00	No	No	
ASBESTOS-ST2-9/5/07	030730438-0002	Southeast Area (sidewalk bridge level)	9/5/07	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/6/07	< 13.00	No	No	
ASBESTOS-ST4-9/5/07	030730438-0003	Northwest Area (street-level)	9/5/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/6/07	< 13.00	No	No	
ASBESTOS-ST5-9/5/07	030730438-0004	Firehouse #10 (roof level)	9/5/07	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/6/07	< 13.00	No	No	
ASBESTOS-ST10-9/5/07	030730438-0005	North Side Sidewalk Bridge	9/5/07	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/6/07	< 13.00	No	No	
ASBESTOS-ST11-9/5/07	030730438-0006	90 Trinity Place (roof level)	9/5/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/6/07	< 13.00	No	No	
ASBESTOS-ST12-9/5/07	030730438-0007	110 Greenwich Street (roof level)	9/5/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/6/07	< 13.00	No	No	
ASBESTOS-ST13-9/5/07	030730438-0008	Marriott Hotel, 38th Floor (roof level)	9/5/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/6/07	< 13.00	No	No	
ASBESTOS-ST14-9/5/07	030730438-0009	West Face - South end at corner (scaffolding level)	9/5/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/6/07	< 13.00	No	No	
ASBESTOS-ST15-9/5/07	030730438-0010	South Face - East end at corner (scaffolding level)	9/5/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/6/07	< 13.00	No	No	
ASBESTOS-ST16-9/5/07	030730438-0011	East Face - North end at corner (scaffolding level)	9/5/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/6/07	< 13.00	No	No	
ASBESTOS-ST17-9/5/07	030730438-0012	North Face - West end at corner (scaffolding level)	9/5/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/6/07	< 13.00	No	No	