

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-9/10/07	030730931-0001	Southwest Area (sidewalk bridge level)	9/10/07	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/11/07	< 13.00	No	No	
ASBESTOS-ST2-9/10/07	030730931-0002	Southeast Area (sidewalk bridge level)	9/10/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/11/07	< 13.00	No	No	
ASBESTOS-ST4-9/10/07	030730931-0003	Northwest Area (street-level)	9/10/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/11/07	< 15.00	No	No	
ASBESTOS-ST5-9/10/07	030730931-0004	Firehouse #10 (roof level)	9/10/07	1	3.060	Asbestos	SEM	EMSL	9/11/07	< 7.12	No	No	
ASBESTOS-ST10-9/10/07	030730931-0005	North Side Sidewalk Bridge	9/10/07	1	3.060	Asbestos	SEM	EMSL	9/11/07	< 7.12	No	No	
ASBESTOS-ST11-9/10/07	030730931-0006	90 Trinity Place (roof level)	9/10/07	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/11/07	< 13.00	No	No	
ASBESTOS-ST12-9/10/07	030730931-0007	110 Greenwich Street (roof level)	9/10/07	1	2.920	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/11/07	< 13.00	No	No	
ASBESTOS-ST13-9/10/07	030730931-0008	Marriott Hotel, 38th Floor (roof level)	9/10/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/11/07	< 13.00	No	No	
ASBESTOS-ST14-9/10/07	030731020-0013	West Face - South end at corner (scaffolding level)	9/10/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/12/07	< 13.00	No	No	
ASBESTOS-ST15-9/10/07	030731020-0014	South Face - East end at corner (scaffolding level)	9/10/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/12/07	< 13.00	No	No	
ASBESTOS-ST16-9/10/07	030731020-0015	East Face - North end at corner (scaffolding level)	9/10/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/12/07	< 13.00	No	No	
ASBESTOS-ST17-9/10/04	030731020-0016	North Face - West end at corner (scaffolding level)	9/10/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/12/07	< 13.00	No	No	
ASBESTOS-ST1-9/11/07	030731020-0001	Southwest Area (sidewalk bridge level)	9/11/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/12/07	< 13.00	No	No	
ASBESTOS-ST2-9/11/07	030731020-0002	Southeast Area (sidewalk bridge level)	9/11/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/12/07	< 13.00	No	No	
ASBESTOS-ST4-9/11/07	030731020-0003	Northwest Area (street-level)	9/11/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/12/07	< 13.00	No	No	
ASBESTOS-ST5-9/11/07	030731020-0004	Firehouse #10 (roof level)	9/11/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/12/07	< 13.00	No	No	
ASBESTOS-ST10-9/11/07	030731020-0005	North Side Sidewalk Bridge	9/11/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/12/07	< 13.00	No	No	
ASBESTOS-ST11-9/11/07	030731020-0006	90 Trinity Place (roof level)	9/11/07	1	2.850	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/12/07	< 13.00	No	No	
ASBESTOS-ST12-9/11/07	030731020-0007	110 Greenwich Street (roof level)	9/11/07	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/12/07	< 13.00	No	No	
ASBESTOS-ST13-9/11/07	030731020-0008	Marriott Hotel, 38th Floor (roof level)	9/11/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/12/07	< 13.00	No	No	
ASBESTOS-ST14-9/11/07	030731020-0009	West Face - South end at corner (scaffolding level)	9/11/07	1	3.770	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/12/07	< 13.00	No	No	
ASBESTOS-ST15-9/11/07	030731020-0010	South Face - East end at corner (scaffolding level)	9/11/07	1	3.780	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/12/07	< 13.00	No	No	
ASBESTOS-ST16-9/11/07	030731020-0011	East Face - North end at corner (scaffolding level)	9/11/07	1	3.730	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/12/07	< 15.00	No	No	
ASBESTOS-ST17-9/11/07	030731020-0012	North Face - West end at corner (scaffolding level)	9/11/07	1	3.790	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/12/07	< 15.00	No	No	