

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-9/13/08	030832264-0001	Southwest Area (sidewalk bridge level)	9/13/08	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/15/08	< 13.00	No	No	
ASBESTOS-ST2-9/13/08	030832264-0002	Southeast Area (sidewalk bridge level)	9/13/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/15/08	< 13.00	No	No	
ASBESTOS-ST4-9/13/08	030832264-0003	Northwest Area (street-level)	9/13/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/15/08	< 13.00	No	No	
ASBESTOS-ST5-9/13/08	030832264-0004	Firehouse #10 (roof level)	9/13/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/15/08	< 13.00	No	No	
ASBESTOS-ST10-9/13/08	030832264-0005	North Side Sidewalk Bridge	9/13/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/15/08	< 13.00	No	No	
ASBESTOS-ST11-9/13/08	030832264-0006	90 Trinity Place (roof level)	9/13/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/15/08	< 13.00	No	No	
ASBESTOS-ST12-9/13/08	030832264-0007	110 Greenwich Street (roof level)	9/13/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/15/08	< 13.00	No	No	
ASBESTOS-ST13-9/13/08	030832264-0008	Marriott Hotel, 38th Floor (roof level)	9/13/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/15/08	< 13.00	No	No	
ASBESTOS-ST14-9/13/08	030832264-0009	West Face - South end at corner (scaffolding level)	9/13/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/15/08	< 13.00	No	No	
ASBESTOS-ST15-9/13/08	030832264-0010	South Face - East end at corner (scaffolding level)	9/13/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/15/08	< 13.00	No	No	
ASBESTOS-ST16-9/13/08	030832264-0011	East Face - North end at corner (scaffolding level)	9/13/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/15/08	< 13.00	No	No	
ASBESTOS-ST17-9/13/08	030832264-0012	North Face - West end at corner (scaffolding level)	9/13/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/15/08	< 13.00	No	No	
ASBESTOS-ST1-9/14/08	030832262-0001	Southwest Area (sidewalk bridge level)	9/14/08	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/15/08	< 13.00	No	No	
ASBESTOS-ST2-9/14/08	030832262-0002	Southeast Area (sidewalk bridge level)	9/14/08	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/15/08	< 13.00	No	No	
ASBESTOS-ST4-9/14/08	030832262-0003	Northwest Area (street-level)	9/14/08	1	3.190	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/15/08	< 13.00	No	No	
ASBESTOS-ST5-9/14/08	030832262-0004	Firehouse #10 (roof level)	9/14/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/15/08	< 13.00	No	No	
ASBESTOS-ST10-9/14/08	030832262-0005	North Side Sidewalk Bridge	9/14/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/15/08	< 13.00	No	No	
ASBESTOS-ST11-9/14/08	030832262-0006	90 Trinity Place (roof level)	9/14/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/15/08	< 13.00	No	No	
ASBESTOS-ST12-9/14/08	030832262-0007	110 Greenwich Street (roof level)	9/14/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/15/08	< 13.00	No	No	
ASBESTOS-ST13-9/14/08	030832262-0008	Marriott Hotel, 38th Floor (roof level)	9/14/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/15/08	< 13.00	No	No	
ASBESTOS-ST14-9/14/08	030832262-0009	West Face - South end at corner (scaffolding level)	9/14/08	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/15/08	< 13.00	No	No	
ASBESTOS-ST15-9/14/08	030832262-0010	South Face - East end at corner (scaffolding level)	9/14/08	1	3.200	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/15/08	< 13.00	No	No	
ASBESTOS-ST16-9/14/08	030832262-0011	East Face - North end at corner (scaffolding level)	9/14/08	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/15/08	< 13.00	No	No	
ASBESTOS-ST17-9/14/08	030832262-0012	North Face - West end at corner (scaffolding level)	9/14/08	1	3.130	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/15/08	< 13.00	No	No	